




Intrusion and Fire Alarm Panel

Signal-10

User's Manual

This User's Manual is intended to help for studying operability principles and maintenance of **Signal-10 Intrusion and Fire Alarm Panel** of version **1.03**.

Please read the instructions completely before connecting, operating, adjusting or maintaining this product.

The following terms are used throughout the Manual:

Alarm Loop (or Loop, or LP): The electrical circuit with non-addressable fire or intrusion detectors (or other non-addressable devices) included. Actuation of a single detector brought in an alarm loop causes breaking of the loop as a whole, so the actuated detector can be located only with the accuracy of the alarm loop.

Zone: A minimal part of a security and safety installation that can be monitored and controlled independently. Depending on the context, the term 'zone' can imply an alarm loop, an addressable detector, a hardware component, and so on.

Partition: A set of zones that can be user controlled as a whole. As a rule, zones fall into partitions depending on their location (e.g., one partition can involve all zones at one individual area)

Arm/Disarm means starting/cancellation monitoring of loop (zone, partition, system) conditions and signaling alarms in controlled zones

Integration Time – a time interval during which sudden alterations of loop resistance are not considered as loop breaking, thus producing no alarms

Network Address (or Address): A unique number of the device (from 1 to 127) within the ISS Orion local RS-485 network

Table of Contents

General	5
Specifications	9
Operation Principles.....	13
<i>Alarm Loops.....</i>	<i>14</i>
Alarm Loop Configuration Parameters	14
Alarm Loop Types	18
<i>Smoke Two Threshold Alarm Loop (Type 1)</i>	<i>19</i>
<i>Combined Fire Single Threshold Alarm Loop (Type 2)</i>	<i>20</i>
<i>Heat Two Threshold Alarm Loop (Type 3).....</i>	<i>21</i>
<i>Intrusion Alarm Loop (Type 4).....</i>	<i>22</i>
<i>Intrusion Alarm Loop with Tamper Monitoring (Type 5).....</i>	<i>22</i>
<i>Auxiliary Alarm Loop (Type 6).....</i>	<i>23</i>
<i>Entrance Alarm Loop (Type 7).....</i>	<i>24</i>
<i>Panic Alarm Loop (Type 11)</i>	<i>25</i>
<i>Programmable Auxiliary Alarm Loop (Type 12).....</i>	<i>25</i>
<i>Fire Threshold Addressable Alarm Loop (Type 14).....</i>	<i>26</i>
Alarm Integration Time	29
Powering Detectors over Alarm Loops	29
<i>Relay Outputs</i>	<i>30</i>
Local Output Control	31
Centralized Output Control	32
<i>Electronic Keys</i>	<i>36</i>
User Keys	36
Master Keys	36
<i>Operating Modes</i>	<i>37</i>
Pre-Operation Mode	37
Operation Mode	37
Power Failure Mode	38
Output Circuit Failure Mode	38
Master Key Programming Mode	38
User Key Programming Mode	38
Self-Diagnostic Mode	39
Device Failure Mode	39
<i>Fire Alarms</i>	<i>40</i>
Conventional Fire Alarm Systems	40
Addressable Fire Alarm Systems	41
<i>Intrusion Alarms.....</i>	<i>43</i>
General Intrusion Alarms.....	43
Intrusion and Detector's Tamper Alarms	44
Entrance Alarms	45
Panic Alarms	46
<i>Auxiliary Alarms.....</i>	<i>48</i>

<i>Loop Status Light and Sound Indication</i>	51
<i>Alarm Loop Arming and Disarming</i>	53
Local Arming/Disarming	53
Centralized Remote Arming/Disarming.....	53
<i>Communications Between the Signal-10 and a Network Controller</i>	55
Transmitting Messages to a Network Controller	55
Installation	59
<i>Standard Delivery</i>	60
<i>Safety Precautions</i>	60
<i>Signal-10 Mounting</i>	60
<i>Wiring the RS-485 Interface Line</i>	62
<i>Connecting External Devices to the Device Outputs</i>	62
<i>Connecting Alarm Loops</i>	64
Including Detectors into Fire Smoke Alarm Loops of the Type 1	64
Including Smoke and Heat Detectors into Alarm Loops of the Type 2.....	65
Including Heat Detectors into Alarm Loops of the Type 3.....	65
Including Intrusion Detectors into Alarm Loops of the Type 4.....	65
Including Intrusion Detectors into Alarm Loops of the Type 5.....	66
Wiring Initiating Devices into Alarm Loops of the Type 14.....	66
<i>Connecting Power Supplies</i>	66
<i>Commissioning</i>	67
Programming	69
<i>Signal-10 System Settings</i>	71
<i>Alarm Loop Programming</i>	74
Loop Type Adjusting	74
Other Loop Parameters Adjusting.....	76
<i>Programming Outputs</i>	79
<i>Key Programming</i>	82
Key Programming by Means of UProg.exe.....	82
Add/Edit a Key.....	83
Delete Key.....	85
Operations with the List of Keys.....	85
Save Results	86
Programming of Keys by Hardware	86
Programming of a Master Key by Hardware	86
Programming of User Keys by Hardware	87
Maintenance	89
<i>Signal-10 Operability Inspection</i>	90
<i>Testing the Signal-10 in Self-Diagnostic Mode</i>	90
<i>Alarm Loop Inspection</i>	91
Annex. Current Consumption Estimation	93

GENERAL



The Signal-10 Intrusion and Fire Alarm Panel (hereinafter referred to as the Signal-10 or the device) is intended to be used in cooperation with an Orion network controller (an S2000M console or a personal computer with Orion Pro software installed) as a control and indicating equipment being part of an

- Intrusion and Panic Alarm System,
- Fire Alarm and Extinguishing System,
- Announcement and Evacuation Management System.

The Signal-10 provides monitoring for up to 10 alarm loops with included detectors and initiating devices. The ways to monitor for the alarm loops and the relevant parameters ("types" of the alarm loops) are to be programmed while configuring the device individually for each alarm loop.

The Signal-10 also can operate in a standalone mode. In such case it works as *single-component control and indicating equipment* (in an intrusion alarm system) which:

- Monitors up to 10 non-addressable alarm loops of the following types:
 - Intrusion Alarm Loop (Type 4);
 - Intrusion Alarm Loop with Tamper Monitoring (Type 5);
 - Entrance Alarm Loop (Type 7);
 - Panic Alarm Loop (Type 11);
 - Auxiliary Alarm Loop (Type 6);
 - Programmable Auxiliary Alarm Loop (Type 12)
- Controls two relay outputs without monitoring connected circuits;
- Controls two switch transistor outputs with monitoring connected circuits;
- Indicates individual states of alarm loops and troubles by its 11 built-in LEDs;
- Supports arming / disarming its alarm loops by means of electronic credentials (iButtons and proximity cards) via the connected external reader;
- Enables operating a group of its alarm loops simultaneously;
- Provides storing in its memory up to 85 credentials along with their rights to operate alarm loops;
- Is powered by one or two unrelated external DC power supplies;
- Is equipped with a tamper switch.

Being a part of an Orion ISS, in cooperation with the Orion network controller (an S2000M console or a personal computer with Orion Pro software installed) the Signal-10 represents a *combined control and indicating device* and managing device.

In spite of functions and features implemented in the standalone mode (listed above), in cooperation with the network controller the Signal-10:

- Monitors up to 10 fire alarm loops
 - o Of non-addressable types, namely:
 - Smoke Two Threshold Alarm Loop (with recognizing responses from one or two detectors within the alarm loop), Type 1;
 - Combined Fire Single Threshold Alarm Loop (both smoke and heat fire detectors can be brought in the alarm loop), Type 2;
 - Heat Two Threshold Alarm Loop, Type 3;
 - o or/and Fire Threshold Addressable Alarm Loops of the Type 14 each of which can monitor up to 10 connected detectors such as DIP-34PA, S2000-IP-PA, and IPR 513-3PA;
- Transmits to the Orion system messages about such events as changing states of alarm loops, attempts to arm / disarm alarm loops, accidental conditions, troubles of the alarm loops, the relay outputs, power and so on;
- Supports centralized control of its outputs, that control being caused by events in the Orion system, such as alarms in intrusion partitions, granting /rejecting access through access points etc.;
- Supports arming / disarming its alarm loops by means of electronic credentials (iButtons or cards) via any reader in the system;
- Supports arming / disarming its alarm loops by means of system push-button keypads or from the network controller;
- Being requested by the network controller, translates the current values of resistance of the alarm loops with connected detectors and initiating devices;
- Stores in its non-volatile memory up to 512 events which cannot be translated to the network controller in case of a temporal communication loss.

Arming/disarming of alarm loops is implemented by using electronic keys which can be Dallas iButtons (Touch Memory devices) or other identifiers with 1-Wire (μ -LAN) output interface. To read electronic keys an external reader is to be connected to the relevant input of the Signal-10. The device provides indication of current partition conditions and results of requested operations by means of two-color reader LED.

The keys have to be pre-programmed, that is enrolled either into the device memory (if alarm loops of the device are armed/disarmed locally) or into the network database (under centralized control) along with the rights to arm/disarms the particular loops of the device assigned to each key.

The device can be powered by one or two (the main and the extra) power supplies providing 12 or 24 Volt of DC. It is strongly recommended to use Bolid manufactured battery backed power suppliers of series RIP-12 or RIP-24.

To program the Signal-10 device for adapting to particular user conditions and meeting specific user needs the Orion device configuration tool, UProg.exe program, has to be used. The latest version of the UProg Configuration Tool can be downloaded from the Bolid website at the address of www.bolid.com. To program the device by means of the UProg, it should be connected to a PC with UProg.exe installed via one of Bolid manufactured interface converters such as PI-GR, S2000-PI, S2000-USB, or USB-RS485.

The Signal-10 is equipped with a tamper switch which provides generating tamper alarms while tamper conditions are changed and transmitting them to a network controller.

The Signal-10 Intrusion and Fire Alarm Panel is intended for indoor installation and round the clock operation. The device is not suitable for operation in corrosive and dusty environments, as well as in fire-hazardous or explosive areas.

SPECIFICATIONS



➤ Indicators (LEDs)	READY LED to indicate device condition and 10 status indicators to indicate statuses of the device alarm loops
➤ Internal Sounder	Built-in
➤ Tamper Switch	Built-in
➤ Event Log Capacity	512 events
➤ RS-485 Communication Port	Yes
<i>Data Transmission</i>	Half-duplex
<i>Transmission Rate</i>	9600 Bd
➤ Power Supply	External 12 to 24 V DC. Bolid manufactured RIP-12 or RIP-24 battery backed power supplies are advisable ¹
➤ Input Voltage	Two inputs (main and backup)
<i>Rated Voltage</i>	10.2 V ÷ 28.4 V DC
<i>Shutdown Voltage</i>	9 V DC
➤ Input Current	220 – 410 mA at 12 V supply voltage, 110 – 200 mA at 24 V supply voltage ²
➤ Pre-Operation Time	3 s maximum provided that at least 11 V steady voltage is applied to one of power inputs
➤ External ID Reader	One Reader Input to connect an external reader of ID such as Dallas Touch Memory devices (iButtons) and so on
<i>Output Interface</i>	Touch Memory (1-Wire, µ-LAN)
<i>Reader LEDs</i>	Two LEDs (Red + Green) controlled by logical +5 V CMOS levels, with current values being restricted by 10 mA at direct connection
➤ ID Memory Capacity	Up to 85 ID codes

¹ The input power voltage is commuted also to the device outputs SIR and LAM to provide power to external sound and light alarms. If the outputs are loaded close to maximum values, it is advisable to power the Signal-10 device from 24 V power supplies

² More precise values can be found at the Annex to this document, see page 93 of this Manual

➤ Alarm Inputs	10 inputs to monitor alarm loops
<i>Detectors to Be Included</i>	Addressable initiating devices DIP-34PA, IPR513-3PA, S2000-IP-PA (up to 10 to each alarm input), or any conventional fire and intrusion detectors intended to be powered by a DC power supply and having the values of internal resistance at Fire mode: No more than 2.7 kΩ for normally open detectors, At least 3.2 kΩ for normally closed detectors
<i>Max Wire Resistance (without regard to termination resistor)</i>	1 kΩ for intrusion alarm loops, 100 Ω for fire alarm loops
<i>Min Leakage Resistance Between Loop Wires or Between Each Wire and the Earth</i>	20 kΩ for intrusion alarm loops, 50 kΩ for fire alarm loops
<i>Loop Voltage</i>	22 V ± 19 V if the termination resistor of 4.7 kΩ ± 5% is brought to the loop and the value of consumed current is 0 to 3 mA (provided that there are no more than 3 short-circuited loops simultaneously), 27 ± 0.5 V if the alarm loop is opened
<i>Max.Short-Circuited Loop Current</i>	26.5 mA
<i>Loop Ripple Voltage</i>	20 mV max
➤ Solid State Relay Outputs	2 outputs ALR1 and ALR2 with normally open contacts intended to transmit alarms and troubles to Central Stations
<i>Commuting Voltage & Current</i>	170 V dc & 0.1 A; 130 V ac & 0.1 A
➤ Transistor Outputs	2 outputs with the possibilities to supervise load circuits for open and short failures; these outputs are intended to connect external sound and light alarms
<i>Commuting Voltage & Current</i>	28 V & 1 A
<i>Load Circuit Supervision Current</i>	3 mA max, the alarms being off
<i>Load Circuit Protection</i>	Resettable fuses
➤ Operating Temperatures	From -30 °C to +50 °C

- **Relative Humidity** Up to 98% at +25 °C
- **Ingress Protection Rating** IP20
- **Overall Dimensions** 156x107x39 mm
- **Weight** about 0.3 kg
- **Average Lifetime** 10 years
- **Device Programming** By means of UProg.exe which is the tool for Orion system device configuration
- **Connection to a PC** Over RS-485 interface bus via one of the Bolid manufactured interface converters PI-GR, S2000-PI, S2000-USB, or USB-RS485

OPERATION PRINCIPLES



ALARM LOOPS

The Signal-10 device provides monitoring for up to ten alarm loops connected to its input contacts. While operating with threshold detectors (opposite to operating with addressable threshold initiating devices which will be described later), the device measures and analyses the effective resistance values of each the connected alarm loop. Depending on:

- The measured resistance value, and
- Whether the loop is armed or disarmed, and
- The algorithm the loop is programmed to be monitored (so called Loop Type)

the Signal-10 assigns this loop to a certain status such as 'Norm', 'Failure', 'Alarm' and so on.

Having analyzed the loop status, the Signal-10 device:

- Indicates the loop status by the related built-in two-color status LED on the device cover
- Emits a specified sound signal by means of the built-in sounder (not for all statuses)
- Activates executive outputs (if programmed)
- While operating as a part of an Orion security system, automatically transmits loop status altering to the Orion network controller

Any fire and intrusion detectors intended to be powered by DC supply can be brought into alarm loops of the Signal-10, the detector internal resistance in Fire mode having to be:

- No more than 2.7 k Ω for normally open detectors and
- No more than 3.2 k Ω for normally closed detectors

Alarm Loop Configuration Parameters

Table 1 shows a set of parameters which can be programmed for the Signal-10 device to define a monitoring algorithm for each the alarm loop of the Signal-10.

The main configuration parameter of each the Signal-10 alarm loop is the **Loop Type**. This parameter defines which way the alarm loop will be monitored for and which detectors can be included into this loop. The Signal-10 supports 10 various types of alarm loops which will be described in details in the next section.

The **Arming Delay** (Exit Delay) parameter defines the time (in seconds), starting from the moment of the receiving the arming command, after elapsing of which the Signal-10 will really attempt to arm the alarm loop. Non-zero Arming Delay values are typically used for *Entrance Alarm Loops* (of the Type 7). Moreover, if one of the Signal-10 outputs is required to be activated before arming an alarm loop, for example, to unset power of 4-wire detectors by means of the 'Switch On for a Time Before Arming' executive program, this alarm loop must obligatory have non-zero Arming Delay (see *Relay Outputs* section of this Manual).

Table 1. Alarm Loops Configuration Parameters

Parameter	Description	Value Range
Loop Type	Defines the tactics the alarm loop to be monitored for, the kind of detectors to be included into the alarm loop, and statuses to be assigned to the alarm loop	1 – Smoke Two Threshold
		2 – Fire Combined (Smoke + Heat) Single Threshold
		3 – Heat Two Threshold
		4 – Intrusion
		5 – Intrusion With Tamper Monitoring (see Note on page 23)
		6 – Auxiliary
		7 – Entrance
		11 – Panic
		12 – Programmable Auxiliary
		14 – Fire Threshold Addressable
Alarm Delay	The delay for switching between Entrance Alarm and Intrusion Alarm statuses, or Fire Prealarm and Fire Alarm statuses	From 1 to 254 s, the '0' value means 'without a delay' the '255' value means 'infinite delay'
Arming Delay	The delay between receiving the arming command and switching the loop to Armed mode	From 0 to 255 s
Auto Rearming After Failing	Automatic switching from Arming Failed status to Armed status when the alarm loop having restored	On / Off
Loop Analysis Delay	The time interval required for transient processes to be completed within the alarm loop after powers resets. During this time the status of the alarm loop will not be analyzed	From 1 to 63 s
Relay 1 ('Alarm 1') Activation Delay	The delay in seconds between having the related alarm loop (loops) broken and activating the relay	From 0 to 255 s
Relay 2 ('Alarm 2') Activation Delay		
Relay 3 ('Siren') Activation Delay		
Relay 4 ('Lamp') Activation Delay		
Never Disarm	The alarm loop cannot be disarmed by any way	On / Off
Auto Arming After Alarm	Automatic switching from the Intrusion Alarm, Panic Alarm, or Fire Alarm status to the Arming Delay status when the alarm loop has been restored	On / Off
Disarmed Loop Monitoring	The directive to transmit over RS-485 interface messages about altering conditions (Norm/No Norm) of the disarmed loop	On / Off

Parameter	Description	Value Range
Fire Loop Requery Prohibition	Being on, disables the function of repeated query for the loop condition for alarm loops of Types 1 and 2	On / Off
300-ms Integration Time	Being on, causes an intrusion alarm loop to enter the Intrusion Alarm status if this one has been broken for more than 300 ms	On / Off
10% Deviation Blocking	Being on, causes an intrusion alarm loop not to enter the Intrusion Alarm status if its resistance value has been changed more than by 10% within 255 s	On / Off
Relay 1 Control	Enables controlling the relevant relay output in relation with this alarm loop condition changing	On / Off
Relay 2 Control		On / Off
Relay 3 Control		On / Off
Relay 4 Control		On / Off
Related Addressable Detectors	For alarm loops of the Type 14 matches the addressable zones of these loops with installed threshold addressable detector and call point addresses	On / Off

The **Alarm Delay** parameter in case of Entrance alarm loop (Type 7) represents the time which is to expire for the device to switch from Entrance Alarm status to the Intrusion Alarm status (that is, the Entry Delay). Its value is selected by such a way that it will be sufficient for a user to disarm the alarm loop after its breaking (after entering the premises) without generating an alarm.

For fire alarm loops (of Types 1, 2, 3, 14) the Alarm Delay represents a timeout for switching from the Fire Prealarm status to the Fire Alarm status. Alarm loops of Types 1, 3, and 14 (two threshold) can also reach the Fire Alarm status if a second fire detector in the loop has actuated. If the value of an Alarm Delay is equal to 255 s, it means that the alarm loop doesn't switch to the Fire Alarm status by time condition (infinite delay). In such a case alarm loops of the Types 1 and 3 can switch to the Fire Alarm status only after actuating of a second detector in the loop, but an alarm loop of the Type 2 never reaches the Fire Alarm status.

If, while arming an alarm loop, the alarm loop resistance is below a normal value, for example, an included smoke fire detector has actuated, the device automatically unsets the loop, that unsets its power for 3 s. **Loop Analysis Delay** for an alarm loop of any type is a pause which is to expire since the power has been restored and until the loop condition will be analyzed. This delay enables including into device alarm loops the detectors with a high worm-up time (or high damping time). If such the detectors are included into an alarm loop, it is necessary to program the Loop Analysis Delay for this alarm loop some more than the maximum worm-up time.

The minimum hardware delay value is 1 s. This value can be increased up to 63 s.

The **Never Disarm** parameter disables disarming the alarm loop by any way. Typically, this parameter is set on for fire and intrusion alarm loops to avoid its accidental disarming. If the alarm loop has the

Intrusion Alarm, or Panic Alarm, or Fire Prealarm, or Fire Alarm, or Arming Failed status, both arming and disarming the alarm loop will lead to attempt to arm the loop.

If an alarm loop has had the Arming Failed status (that is, was broken in the moment of being armed and the **Auto Rearming After Failing** attribute is set on for the alarm loop, the alarm loop will automatically be armed when its resistance comes back to a normal value and is kept normal for more than 3 s.

If an alarm loop has switched to the Intrusion Alarm, or Panic Alarm, or Fire Alarm status and the **Auto Arming After Alarm** attribute is set on for the alarm loop, the loop will automatically be armed when its resistance comes back to a normal value and is kept normal for more than the time interval equal to 15 times Alarm Delay values (in seconds).

The **Disarmed Loop Monitoring** parameter causes the Signal-10 to monitor the alarm loop also in the Disarmed status. If the resistance of the loop is normal, the Signal-10 transmits a network controller a READY TO ARM message, otherwise, if the loop is broken, a NOT READY TO ARM message is transmitted. The integration time for the disarmed loop broken status is 300 ms, while to consider the disarmed loop as being in norm the integration time is equal to the Alarm Delay value.

The **Relay 1...4 Control** parameters relates alarm loops to required relay outputs of the Signal-10. If statuses of an alarm loop must affect on conditions of one or several device outputs, the relevant parameter for the alarm loop must be set on.

If any output of the Signal-10 must be activated by remote commands of a network controller (that is, in case of centralized control), then the relevant control parameter for this output must be off for all the alarm loops of the Signal-10.

If changing of alarm loop statuses must lead to switching of any relay output in accordance with an assigned executive program (see *Relay Outputs* section of this Manual), switching will be delayed for a time given for the loop by a **Relay 1...4 Activation Delay**. For some particular executive programs such as 9 (*Lamp*), 10 (*Alarm Output*), 13 (*Fire Output*), 14 (*Trouble Output*), 15 (*Fire Lamp*) и 16 (*Alarm Output 2*), see Table 5, the Relay Activation Relay is ignored and the relay output is switched immediately after loop status changing.

The **Fire Loop Requery Blocking** parameter, being set on, disables the function of the repeated query of the conditions of the alarm loops of Types 1 and 2 after a detector within the loop has actuated. Thus, if the Fire Loop Requery Blocking is set on, actuating of a single fire detector within the alarm loop will immediately switch the loop to the Fire Prealarm status.

The **300-ms Integration Time** parameter enables to set the integration time for intrusion alarm loops (of the Types 4, 5, 7, and 11). The value "On" corresponds to the integration time equal to 300 ms, while the "Off" one corresponds to that equal to 70 ms. In order to decrease false alarms the integration time of 70 ms must be selected only if it is strongly necessary.

The **10% Deviation Blocking** parameter disables intrusion alarm loop's analysis in case of sharp distinctions of loop resistance (more than by 10% from a steady-stated value) not skipping though out of

the normal range. It is advisable to set this parameter on for such the alarm loops which involve detectors producing high voltage ripples in the alarm loop.

The **Related Addressable Detectors** parameters relates an alarm loop of the Type 14 (the threshold addressable alarm loop) with the addresses of the already installed into the loop addressable detectors or call points – see *Fire Threshold Addressable Alarm Loop (Type 14)* section of this Manual. If the addressable zone of an addressable detector or call point is not related to an alarm loop, this zone doesn't take part in generating of a generalized loop and is not affected by loop arming/disarming commands.

Alarm Loop Types

The main alarm loop configuration parameter which defines the way the controller considers the conditions of the alarm loop is the **Loop Type**. The Signal-10 supports 10 different types of alarm loops.

Table 2 shows how the current resistance values of alarm loops are considered by the Signal-10 device to be different loop statuses depending on the current type of the alarm loop.

Table 2. Alarm Loop Resistance Values for Different Loop Statuses

Loop Type	Alarm Loop Conditions and Statuses				
Type 1 Smoke Two Threshold	Short Circuit	Fire Alarm (two or more smoke detectors have actuated)	Fire Prealarm (a smoke detector has actuated)	Norm	Open Circuit
	Less than 100 Ω	From 150 Ω to 1.56* kΩ	From 1.1* kΩ to 1.8 kΩ	From 2.2 to 5.4 kΩ	More than 6.6 kΩ
		* Depends on the loop load current			
Type 2 Fire Combined Single Threshold	Short Circuit	Fire Prealarm/ Fire Alarm (a smoke detector has actuated)	Norm	Fire Prealarm/ Fire Alarm (a heat detector has actuated)	Open Circuit
	Less than 100 Ω	From 150 Ω to 1.8* kΩ	From 2.2 to 5.4 kΩ	From 6.6 to 14.4 kΩ	More than 16 kΩ
Type 3 Heat Two Threshold	Short Circuit	Norm	Fire Prealarm (a heat detector has actuated)	Fire Alarm (two or more heat detectors have actuated)	Open Circuit
	Less than 1.8 kΩ	From 2.2 to 5.4 kΩ	From 6.6 to 11 kΩ	From 12.5 to 22.5 kΩ	More than 25 kΩ
Type 4 Intrusion	Norm		Intrusion Alarm		
	From 2.2 to 10 kΩ		Less than 1.8 kΩ, or more than 12 kΩ, or has jumped by more than 10 %		

Loop Type	Alarm Loop Conditions and Statuses				
Type 5 Intrusion With Tamper Monitoring	Norm	Intrusion Alarm	Detector Enclosure Tampering		
	From 2.2 to 5.4 kΩ	Less than 1.8 kΩ or more than 6.6 kΩ (if armed)	From 6.6 kΩ to 9.0 kΩ, or less than 100 Ω, or more than 20 kΩ (if the loop have the Disarmed, or Arming Delay, or Arming Failed statuses)		
Type 6 Auxiliary	Norm of Auxiliary alarm loop		Auxiliary alarm loop breaking		
	From 2.2 to 5.4 kΩ		Less than 1.8 kΩ or more than 6.6 kΩ		
Type 7 Entrance	Norm		Entrance/Intrusion Alarm		
	From 2.2 to 5.4 kΩ		Less than 1.8 kΩ, or more than 6.6 kΩ, or has jumped by more than 10 %		
Type 11 Panic	Norm		Silent Alarm (Attack)		
	From 2.2 to 5.4 kΩ		Less than 1.8 kΩ, or more than 6.6 kΩ, or has jumped by more than 10 %		
Type 12 Programmable Auxiliary	Status 1*	Status 2*	Status 3*	Status 4*	Status 5*
	Less than R1*	from R1* to R2*	from R2* to R3*	from R3* to R4*	More than R4*
	* – alarm loop statuses and threshold loop resistance values are user programmable (see <i>Auxiliary Alarms</i> section of this Manual)				

Smoke Two Threshold Alarm Loop (Type 1)

A loop of the Type 1 (Smoke Two Threshold) is intended to involve fire smoke (normally open) detectors. This loop is considered to be in one of the following statuses:

Armed	The alarm loop is monitored, its resistance being normal
Disarmed	The alarm loop is not monitored
Arming Delay	The Arming Delay has not yet expired
Fire Prealarm	A single detector has actuated within the alarm loop
Fire Alarm	At least two detectors brought in the alarm loop have actuated, or the Alarm Delay has expired after single detector actuation
Short Circuit Failure	The resistance of the alarm loop is less than 100 Ω
Open Circuit Failure	The resistance of the alarm loop is more than 6 kΩ
Arming Failed	The alarm loop has been broken at the moment of being armed

An included detector having actuated, the Signal-10 generates FIRE SIGNAL message and repeatedly queries the condition of the alarm loop by doing the following. The device unset loop power for 3 s. If within 55 s after power reset the detector actuates repeatedly, then the alarm loop is considered to be in the Fire Prealarm status. Otherwise, if the detector has not actuated repeatedly within 55 s, the alarm

loop is considered to be in Armed status. The alarm loop can switch from the Fire Prealarm status to the Fire Alarm status if a second detector included into this alarm loop has actuated, as well as the given Alarm Delay has expired. (If Alarm Delay is set with zero value, Fire Prealarm status will switch to Fire Alarm status immediately.) The Alarm Delay value of 255 s (the maximum possible value) corresponds to unlimited timeout, such as switching from the Fire Prealarm status to the Fire Alarm status is implemented only after actuating of another detector included into the alarm loop.

The integration time for an alarm loop of the Type 1 is defined in accordance with the requirements mentioned in the *Alarm Integration Time* section of this Manual on the page 29.

Table 2 shows the matching between current resistance values and corresponding statuses of alarm loops of the Type 1.

The wiring diagram for including fire smoke (normally open) detectors into alarm loops of the Type 1 is presented on the page 64.

Combined Fire Single Threshold Alarm Loop (Type 2)

A loop of the Type 2 (Combined Fire Single Threshold) is intended to involve fire smoke (normally open) and heat (normally closed) detectors. This loop is considered to be in one of the following statuses:

Armed	The alarm loop is monitored, its resistance being normal
Disarmed	The alarm loop is not monitored
Arming Delay	The programmed Arming Delay has not been expired
Fire Prealarm	Either activation of a heat detector or repeated activation of a smoke detector is recognized within the loop
Fire Alarm	The Alarm Delay has expired after single detector actuation
Short Circuit Failure	The resistance of the loop is less than 100 Ω
Open Circuit Failure	The resistance of the loop is more than 16 K Ω
Arming Failed	An attempt to arm the loop has failed because the loop is broken

A heat detector having actuated, the loop switches to the Fire Prealarm status.

When a smoke detector has actuated, the Signal-10 generates a FIRE SIGNAL message and repeatedly queries condition of the loop (see above, for a loop 1). If detector actuation is confirmed, the loop switches to the Fire Prealarm status.

The loop can switch from the Fire Prealarm status to the Fire Alarm status after expiring of the given Alarm Delay. If the value of the given Alarm Delay equals to zero, then the loop will switch from the Fire Prealarm status to the Fire Alarm status immediately. The Alarm Delay value of 255 s (maximum possi-

ble value) means unlimited time delay, so the loop never switches from the Fire Prealarm status to the Fire Alarm status.

The integration time for an alarm loop of the Type 2 is defined in accordance with the requirements mentioned in the *Alarm Integration Time* section of this Manual on the page 29.

Table 2 shows the matching between current resistance values and corresponding statuses of alarm loops of the Type 2.

The wiring diagram for including fire smoke (normally open) and fire heat (normally closed) detectors into alarm loops of the Type 2 is presented on the page 65.

Heat Two Threshold Alarm Loop (Type 3)

A loop of the Type 3 (Heat Two Threshold) is intended to involve fire heat (normally closed) detectors. This loop is considered to be in one of the following statuses:

Armed	The alarm loop is monitored, its resistance being normal
Disarmed	The alarm loop is not monitored
Arming Delay	The programmed Arming Delay has not been expired
Fire Prealarm	A single detector has actuated within the alarm loop
Fire Alarm	At least two detectors brought in the alarm loop have actuated, or the Alarm Delay has expired after single detector actuation
Short Circuit Failure	The resistance of the loop is less than 2 k Ω
Open Circuit Failure	The resistance of the loop is more than 25 K Ω
Arming Failed	An attempt to arm the loop has failed because the loop is broken

An included detector having actuated, the loop switches to the Fire Prealarm status. The loop can switch from the Fire Prealarm status to the Fire Alarm status if a second detector in the loop has actuated, or a given Alarm Delay has expired. If the Alarm Delay is equal to zero, then the loop switches from the Fire Prealarm status to the Fire Alarm status immediately. The Alarm Delay value of 255 s (maximum possible value) is considered as infinite time delay, when switching from the Fire Prealarm status to the Fire Alarm status can be implemented only after actuation of a second detector within this alarm loop.

The integration time for an alarm loop of the Type 3 is defined in accordance with the requirements mentioned in the *Alarm Integration Time* section of this Manual on the page 29.

Table 2 shows the matching between current resistance values and corresponding statuses of alarm loops of the Type 3.

The wiring diagram for including fire heat (normally closed) detectors into alarm loops of the Type 3 is presented on the page 65.

Intrusion Alarm Loop (Type 4)

A loop of the Type 4 (Intrusion) is intended to involve any intrusion detectors, both normally open and normally closed, and powered either over the loop or separately. This loop is considered to be in one of the following statuses:

Armed	The alarm loop is monitored, its resistance being normal
Disarmed	The alarm loop is not monitored
Arming Delay	The programmed Arming Delay has not yet expired
Intrusion Alarm	The alarm loop has been broken
Arming Failed	An attempt to arm the loop has failed because the loop is broken

An Intrusion alarm loop is considered to be broken if its resistance goes out of normal range as well as jumps by more than (provided that the 10% Deviation Blocking parameter is set off). Breaking an intrusion loop causes it to enter the Intrusion Alarm status.

An alarm integration time for this type of alarm loops can be 70 ms or 300 ms depending on the programmed value of the 300-ms Integration Time parameter.

Table 2 shows the matching between current resistance values and corresponding statuses of alarm loops of the Type 4.

The wiring diagram for including intrusion detectors into alarm loops of the Type 4 is presented on the page 65.

Intrusion Alarm Loop with Tamper Monitoring (Type 5)

A loop of the Type 5 (Intrusion with Tamper Monitoring) is intended to involve a single intrusion detector and the tamper switch of this detector. This loop is considered to be in one of the following statuses:

Armed	The alarm loop is monitored, its resistance being normal
Disarmed	The alarm loop is not monitored
Arming Delay	The programmed Arming Delay has not yet expired
Intrusion Alarm	The alarm loop has been broken
Arming Failed	An attempt to arm the loop has failed because the loop is broken
Tamper Alarm	The enclosure of the disarmed detector has been tampered, or short circuit failure of the disarmed loop has been detected

When the alarm loop is armed, either any skip of the resistance value (by more than 10%), or actuation of the detector (opening of its alarm contact), or tamper switch actuation causes the loop to be considered as being in the Intrusion Alarm status. When the alarm loop is disarmed, either tamper switch actuation or loop short circuit failure causes the alarm loop to be considered as being in the Tamper Alarm status.

An alarm integration time for this type of alarm loops can be 70 ms or 300 ms depending on the programmed value of the 300-ms Integration Time parameter.

Table 2 shows the matching between current resistance values and corresponding statuses of alarm loops of the Type 5.

The wiring diagram for including an intrusion detectors and its tamper switch into an alarm loop of the Type 5 is presented on the page 66.

NOTE: Please take into account the following using an alarm loop of the Type 5.

If such alarm loop is disarmed when the detector brought in the loop has been responded, in addition to receiving the Disarmed message you can receive some additional messages: Tamper Alarm and Tamper Restored, the last message being received after 15 s since restoring the detector. These additional messages are due to specific operation of the device of this version and don't show actual conditions of the detector's tamper switch.

So, you are not recommended to use the Type 5 in cases when alarm loops are to be supposed to be disarmed after a detector's response (after entering into the protected area).

If such alarm loop is disarmed when the detector is in quiescent mode, no additional messages are received.

Auxiliary Alarm Loop (Type 6)

Auxiliary alarm loops (loops of the Type 6) are intended to monitor operability and conditions of fire-fighting equipment as well as sensors and indicators not related directly with fire or intrusion alarms. Devices with dry contact (both normally closed and open) or open collector outputs can be included into such alarm loop.

This loop is considered to be in one of the following statuses:

Auxiliary Zone Restored

Auxiliary Zone Alarm



If the resistance of the alarm loop of the Type 6 has been out of the normal range for more than 300 ms, then the alarm loop is considered to be in the Auxiliary Zone Alarm status. When the loop is restored (that is, its resistance has been within normal range for more than Arming Delay seconds), the loop is considered to be in the Auxiliary Restored Status.

Table 2 shows the matching between current resistance values and corresponding statuses of alarm loops of the Type 6.

An auxiliary alarm loop is *always* monitored; it cannot be blocked or disarmed. If the arming command addressed to this loop is received, the device responds with the message about its current status.

When a status of an Auxiliary alarm loop has changed the Signal-10 transmits a relevant message to a network controller. The events related to Auxiliary alarm loop are not stored in the Signal-10 non-volatile memory. Thus, if a status of an Auxiliary alarm loop has changed several times during communication loss, after communication having restored the network controller receives either a single last message or no message if the current status of the loop is just like as the last transmitted status.

If an Auxiliary alarm loop is related to a Signal-10 relay output, then its breaking locks starting the relay in accordance with executive programs ##1 – 8 (general-purpose), #11 (ASPT), #2 (Siren), #33 (ASPT-1), #34 (ASPT-A), #35 (ASPT-A1), see Table 5. This functionality is suitable, for example, to lock automatic starting of gas firefighting installations when a door in protected premises is open.

All normally closed and normally open detectors and other devices with dry contact outputs are included into Auxiliary alarm loops similarly to that how intrusion detectors are included to alarm loops of the Type 4 (see the page 65).

Entrance Alarm Loop (Type 7)

A loop of the Type 7 (Entrance) is intended to involve any intrusion detectors, both normally open and normally closed, and powered either over the loop or separately. This loop is considered to be in one of the following statuses:

Armed	The alarm loop is monitored, its resistance being normal
Disarmed	The alarm loop is not monitored
Arming Delay	The programmed Arming Delay has not yet expired
Entrance Alarm	The alarm loop has been broken
Intrusion Alarm	Since breaking of the alarm loop the time of given Alarm Delay has been expired
Arming Failed	An attempt to arm the loop has failed because the loop is broken

An Entrance alarm loop is operated similarly to an Intrusion alarm loop, except this loop switches to the Entrance Alarm status immediately after its breaking. Then, if this alarm loop is not disarmed or armed until the Alarm Delay has been expired, the loop switches to the Intrusion Alarm status.

While the alarm loop is being in the Entrance Alarm status, no relay controlled in accordance with one of the general-purposed executive programs (#1 – #8) or Siren program (# 12) is activated.

An alarm integration time for this type of alarm loops can be 70 ms or 300 ms depending on the programmed value of the 300-ms Integration Time parameter.

Table 2 shows the matching between current resistance values and corresponding statuses of alarm loops of the Type 7.

The wiring diagram for including intrusion detectors into an alarm loop of the Type 7 is similar to that presented on the page 65.

Panic Alarm Loop (Type 11)

All kinds of normally closed and normally open panic buttons, pedals and so on can be brought into a Panic alarm loop (Type 11). This loop is considered to be in one of the following statuses:

Armed	The alarm loop is monitored, its resistance being normal
Disarmed	The alarm loop is not monitored
Arming Delay	The programmed Arming Delay has not yet expired
Panic Alarm	Breaking the loop has been detected
Arming Failed	An attempt to arm the loop has failed because the loop is broken

A Panic alarm loop is operated similarly to an Intrusion alarm loop, except this loop switches to the Panic Alarm status after it has been broken.

The Panic Alarm status is indicated only by the relevant Signal-10 LED and can initiate only that related relay which is programmed to operate in accordance with Alarm Output 1 (#10) or Alarm Output 2 (#16) executive programs (the relay contacts being opened). The internal sounder of the Signal-10 also is not activated upon Panic Alarm.

An alarm integration time for this type of alarm loops can be 70 ms or 300 ms depending on the programmed value of the 300-ms Integration Time parameter.

Table 2 shows the matching between current resistance values and corresponding statuses of alarm loops of the Type 11.

The wiring diagram for including panic buttons into an alarm loop of the Type 11 is similar to that presented on the page 65.

Programmable Auxiliary Alarm Loop (Type 12)

This type of loop monitoring methods can be used to monitor the conditions of various equipment and detectors, including those which are not related directly with fire and intrusion alarms. Any detectors or devices with dry contact or open collector outputs can be included into an alarm loop of the Type 12.

A Programmable Auxiliary alarm loop can be in one of five different statuses which match each to its own resistance range. These statuses and resistance values matched with them are user programmable. Accordingly, if a device can be in one of some different conditions and has several output contacts, this device can be monitored by means of a single alarm loop. In such a case the output contact of the device must be included into the alarm loop along with different additional or shunt resistors. By such a manner the loop can be monitored for short and open failures.

Sound and light indication of the Signal-10 as well as the way this loop impacts on a related relay (that is, the executive program assigned with the relay) are defined by the statuses this loop can reach. Table 7 displays the list of statuses which can be programmed for an alarm loop of the Type 12, while Table 5 shows the list of available executive programs taking into account different loop statuses.

The switching between statuses of a Programmable Auxiliary alarm loop is defined only by changing its resistance and is not affected by any other loop parameters or network controller commands. The integration time for switching between statuses is generally equal to 300 ms. But if an alarm loop of the Type 12 has entered such status as Armed, Disarmed, Auxiliary Zone Restored, or any other "... Restored", the integration time for this status is equal to a programmed Arming Delay value.

A Programmable Auxiliary alarm loop is *always* monitored and cannot be blocked or disarmed. If the arming command addressed to this loop is received, the device responds with the message about its current status.

When the statuses of alarm loops of the Types 12 are changed the Signal-10 transmits the network controller relevant messages. The events due to Programmable Auxiliary alarm loop are not stored in the nonvolatile device memory similarly to loops of the Type 6.

Fire Threshold Addressable Alarm Loop (Type 14)

The Signal-10 supports operating with addressable detectors DIP-34PA and S2000-IP-PA in threshold addressable mode as well as IPR513-3PA manual call points. To implement this, special Fire Threshold Addressable alarm loops (loops of the Type 14) are intended. Up to ten DIP-34PA, S2000-IP-PA, or IPR513-3PA can be included into such the alarm loop, thus enabling to build up to 100 addressable zones based on a single Signal-10 device. The Signal-10 periodically polls connected detectors providing monitoring its operability and indication of malfunctioning or activated detectors. A response time of each detector doesn't exceed 10 s.

NOTE: Statuses of each addressable zone of each loop of the Type 14 (each detector or call point connected to the Signal-10) can be displayed separately only by a network controller. Thus, an addressable system can be fully implemented if the Signal-10 cooperates with the network controller.

Each threshold addressable detector or call point included into an alarm loop of the Type 14 is considered as an additional addressable zone of the Signal-10. Each alarm loop can include up to 10 addressable zones which numbers range from 20 to 119. The digital number of a Signal-10 addressable

zone is formed by adding the own detector or call point address (ranged from 1 to 10) to 10 times the number of the loop incremented by one, so that:

Detectors connected to the contact	LP1	are assigned to addressable zones	20-29
	LP2	—	30-39
	LP3	—	40-49
	LP4	—	50-59
	LP5	—	60-69
	LP6	—	70-79
	LP7	—	80-89
	LP8	—	90-99
	LP9	—	100-109
	LP10	—	110-119

NOTE: No threshold addressable detectors or call points with the same own address can be included into the same fire loop of the Type 14

The Signal-10 recognizes the following messages/conditions responded by addressable devices:

- Norm
- Dusty, Service Required
- Trouble
- Fire
- Manual Fire Alarm
- Test
- Isolated

A current condition of an alarm loop of the Type 14 is formed as a generalized condition of those addressable zones which are involved into this loop and matched with this loop by the given Related Addressable Detectors setting (see *Alarm Loop Configuration Parameters* section of this Manual). The generalized condition of a loop of the Type 14 is defined as the most priority condition of all the addressable zones.

Following are all possible generalized conditions of a threshold addressable loop in the order of priority:

Fire Alarm	Two or more loop addressable zones have the Fire Alarm status, or the Alarm Delay given for this loop has been expired
Fire Prealarm	There is at least one addressable zone in the Fire Alarm status
Trouble	There is an addressable zone with the Trouble status, and there is no zone with the Fire Alarm status
Isolated	There is an isolated addressable zone in the loop, while there are no zones with Fire Alarm or Trouble statuses

Fire Signal	There is an addressable zone with Test status and there are no zones with Isolated, Trouble, or Fire Prealarm, or Fire Alarm statuses
Arming Failed	At the moment of arming, one of the addressable zones of the loop has a not Norm status, no other zones having more priority statuses (said above)
Arming Delay	The transient status when after an attempt to arm an addressable zone the response from the addressable detector is waiting for, and there are no zones with more priority statuses (said above)
Dusty Sensor, Service Required	There is an addressable zone with the Dusty status, all other zones being in Norm
Disarmed	There is a disarmed addressable zone within the loop, all other zones of the loop being armed
Armed	All addressable zones are in norm and armed

If a Fire condition has been detected for an addressable zone of a fire threshold addressable alarm loop, this loop switches to the Fire Prealarm status. If Fire conditions have been detected for two different addressable zones of a loop, the loop switches to the Fire Alarm status. The loop also can switch from the Fire Prealarm to Fire Alarm status after the programmed Alarm Delay having expired. If the Alarm Delay is set to zero for this loop, the loop switches to the Fire Alarm status after a single detector having actuated. If the Alarm Delay is set to 255 (infinite delay), the loop can switch to the Fire Alarm status only after two detectors having actuated.

If the Signal-10 has no response from an addressable detector within 10 s, the *Isolated* status is assigned to its addressable zone. In such a case the function of breaking the loop to remove the detector from its mounting base can be avoided and all other detectors in the loop keep their operability. No termination resistor is included into a fire threshold addressable alarm loop. The loop can be of any topology such as a bus, a ring, a star, or any hybrid topology.

While programming the Signal-10, it is possible to specify in advance the addresses of those detectors which will be included into this threshold addressable alarm loop. It is implemented by the Related Addressable Devices parameter setting. If the matching an addressable zone to a particular alarm loop is missed, then this zone is not considered when a generalized status of the alarm loop is formed and is not affected by arming/disarming commands while the loop is armed/disarmed.

Alarm Integration Time

The time interval, during which short-time loop resistance changes are not considered as its breaking and don't lead to any alarms (that is, the Alarm Integration Time), is equal to or less than:

- 50 ms for an intrusion alarm loop if the 300-ms Integration Time parameter is set off for this loop
- 250 ms for other alarm loops and those intrusion alarm loops for which the 300-ms Integration Time parameter is on

The time interval, after expiration of which resistance changes of a loop are considered as its breaking and cause the Signal-10 to generate alarms, is equal or more than:

- 70 ms for an intrusion alarm loop if the 300-ms Integration Time parameter is set off for this loop
- 300 ms for an intrusion alarm loop or Auxiliary alarm loop if the 300-ms Integration Time parameter is set on for this loop

For alarm loops of the Types 1, 2, 3 breaking the loop causing the device to generate an alarm can lasts from 300 ms to 3 s depending on transient processes occurring within the loop. If high capacity detectors are included into the alarm loop, the Alarm Integration Time increases inversely to transient process rate. The minimum loop voltage change rate corresponding to maximum Alarm Integration Time is 0.5 V/s.

Powering Detectors over Alarm Loops

The Signal-10 supplies power over alarm loops to two-wire fire and intrusion detectors. The number of detectors to be included in a single alarm loop is calculated by formula:

$N = I_m / i$, where:

N is the number of detectors in the alarm loop

I_m is the maximum load current

$I_m = 3 \text{ mA}$ for alarm loops of Types 1, 4, 6, 7, 11, 12 and $I_m = 1.2 \text{ mA}$ for alarm loops of Type 2

i is the current in mA consumed by a detector in quiescent mode

If an alarm loop of the Type 1 (fire smoke) is in use, fire detectors must keep their operability upon lowering the voltage until 12 V.

RELAY OUTPUTS

The Signal-10 device is equipped with four executive outputs, among them

- Two solid state relays ALR1 and ALR2 with normally open contacts, galvanic isolation, and switching capacity of 170 V dc / 0.1A or 130 V ac / 0.1A, and
- Two transistor outputs SIR and LAM with output switching capacity of 28V/1A which can be monitored for load circuit troubles and provide overcurrent protection by means of resettable fuses

The SIR and LAM outputs are usually used to connect external sound and light alarms indicating alarms and troubles. Outputs ALR1 and ALR2 are intended for separate transmission of fire alarms and troubles in fire safety systems, or for transmission fire and intrusion alarms to central guard stations, central monitoring stations, fire brigades, and so on. Optionally the relay outputs can be adapted to meet individual user requirements, for example, to unset power of four wire detectors before its will be armed, or to turn on/off various technical equipment (such as heaters, coolers, ventilators, air conditioners, etc.) in case of alarm loops of Type 12 status altering.

Table 3 shows the programmable parameters of Signal-10 outputs.

Table 3. Signal-10 Outputs Configuration Parameters

Parameter	Description	Value Range
Executive Program	Defines the initial relay on/off condition and the way the output will be controlled depending on the status of the alarm loops related with this output	1 ... 37
Relay Activation Time	Defines the time interval for which the relay will be switched on/off if the assigned executive program implies the limited activation time	0 s to 8192 s (up to 2 hours 16 minutes 32s) in increments of 0.125 s
Relay ON/OFF Events	Enables/disables event transmissions in case of output on/off condition altering in order to display on system indicator modules or to log these events in system database	On / Off
Monitor For	Defines the load circuit monitoring tactics for outputs SIR (the relay 3) and LAM (the relay 4)	1 – Without Monitoring 2 – Open Failure 3 – Short Failure 4 – Open and Short Failure

The Signal-10 outputs ALR1, ALR2, SIR, and LAM can be controlled in two ways:

- Locally in accordance with an assigned executive program depending on statuses of related alarm loops (see below)
- Remotely by network controller commands

The **Monitor For** parameter for outputs SIR and LAM defines the kinds of troubles of external device circuits connected to these outputs which will be monitored for during Signal-10 operating. The failures such as open circuit failures, short circuit failures, or both open and short failures will be monitored without regard to is the relay output switched on or off. Setting this parameter to the value *Without Monitoring* disables monitoring for troubles of the SIR or LAM output circuit. Table 4 shows how the Signal-10 considered the values of load circuit resistances to match the various circuit conditions.

The **Relay ON/OFF Events** parameter can be set on individually for each relay output. If the parameter is set on then output condition altering is transmitted to a network controller.

Table 4. Output Circuit Conditions Depending on Effective Loading Resistance

Norm		Open Circuit		Short Circuit	
Output is on	Output is off	Output is on	Output is off	Output is on	Output is off
26 Ω to 10 k Ω		More than 12 k Ω (upon supply voltage 12 V)	More than 10 k Ω	Less than 24 Ω	
		More than 25 k Ω (upon supply voltage 24V)			

Local Output Control

In order to control automatically a device output depending on alarm loop condition (that is, local control) do the following:

- While programming the alarm loop (loops), assign this loop (these loops) to the required relay by means of the relevant **Relay ... Control** parameter and define if necessary the required **Relay Activation Delay** value (see the *Alarm Loop Configuration Parameters* Section of this Manual)
- While programming the device outputs, assign this relay output to a suitable Executive Programs and give if necessary a suitable **Relay Activation Time**

An **Executive Program** defines the method the relay output will be controlled depending on current status of the alarm loops related with the relay output and the initial condition of the relay after power-on the Signal-10. Table 5 describes all available executive programs for the Signal-10 device.

A **Relay Activation Time** gives the time interval the relay will be activated for (switched on or off) if the assigned executive program implies the limited activation time. The maximum time interval the relay can be activated for is 8192s, that is 65535 intervals each of 0.125s.

For all the executive programs except #9, #10, #13, #14, #15, #16 (see Table 5), switching the relay output on (off) upon the alarm loop status changing can be delayed for the time given by the relevant **Relay Activation Delay** value for each alarm loop. Therefore, a relay output can be activated at different times depending on the particular alarm loop which status changing switches the relay and Relay Activation Delay value specified for this loop.

For executive programs #1 – #8 (general purpose programs), #11 (ASPT), #12 (Siren), #33 (ASPT-1), #34 (ASPT-A), #35 (ASPT-A1) in case of breaking an Auxiliary alarm loop (of Type 6) related with an output, switching this output from other related alarm loops is blocked. If upon the recovering of the Auxiliary loop the conditions for switching the relay remains then:

- for the executive programs with unlimited activation time (#1, #2, #5, #6) as well as programs #12 (ASPT) and #33 (ASPT-1) the relay output will be switched again, but
- for the executive programs #3, #4, #7, #8, #34, #35 the output will NOT be switched

Thus, breaking of an Auxiliary alarm loop blocks an execution of the general purpose programs with unlimited activation time as well as the programs *ASPT* and *ASPT-1*, and cancels the execution of the general purpose programs with a restricted activation time as well as *Siren*, *ASPT-A*, *ASPT-A1*.

NOTE: *Local control of relay outputs is more significant than centralized control.* That is, if a relay output is related to an alarm loop status in the device settings then remote control commands of a network controller over RS-485 interface will be ignored.

Centralized Output Control

To enable centralized control for a Signal-10 relay output:

- In alarm loop settings, break an association between the output and any alarm loop of the device (that is, the **Relay ... Control** parameters for this output must be set OFF for all the alarm loops of the Signal-10
- In output settings, assign this relay output to any **Executive Program** with a suitable initial relay on/off condition
- In the network controller database, assign the output with relevant Orion system partitions and give a required executive program along with a proper activation time and activation delay.

Table 5. Executive Programs for Relay Outputs

№	Program	Description	Initial Condition
0	Remote Control	The relay is controlled only remotely	Off
1	Switch On	The relay is switched on if there is an Intrusion Alarm or Fire Alarm	Off
2	Switch Off	The relay is switched off if there is an Intrusion Alarm or Fire Alarm	On
3	Switch On for a Time	The relay is switched on for a specified time if there is an Intrusion Alarm or Fire Alarm	Off
4	Switch Off for a Time	The relay is switched off for a specified time if there is an Intrusion Alarm or Fire Alarm	On
5	Blink From Off Condition	The relay is switched on/off once per second if there is an Intrusion Alarm or Fire Alarm	Off

№	Program	Description	Initial Condition
6	Blink From On Condition	The relay is switched on/off once per second if there is an Intrusion Alarm or Fire Alarm	On
7	Blink for a Time From Off Condition	The relay is switched on/off once per second for a specified time if there is an Intrusion Alarm or Fire Alarm	Off
8	Blink for a Time From On Condition	The relay is switched on/off once per second for a specified time if there is an Intrusion Alarm or Fire Alarm	On
9	Lamp	In case of a Fire Alarm the relay is switched on/off alternately twice per second In case of a Fire Prealarm the relay is switched on for a short time every second In case of an Intrusion Alarm, or Entrance Alarm, or Arming Failed the relay is switches on/off alternately once per second In case of a Trouble the relay is switched on for a short time once per two seconds If an alarm loop is armed the relay is switched on If all alarm loops are disarmed the relay is switched off	*
10	Alarm Output 1	If all the alarm loops related with the relay are armed then the relay is switched on, otherwise the relay is switched off	*
11	ASPT	The relay is switched on for a given time if two or more alarm loops related with the relay have Fire Alarm status and there are no Auxiliary loops broken. The broken Auxiliary loop will block switching on. If the Auxiliary loop is broken while the Relay Activation Delay has not yet expired then, after recovering of the loop, the relay output will be switched on for a specified time. (That is, breaking of the Auxiliary loop temporary blocks activation delay counting.)	Off
12	Siren	In case of a Fire Alarm the relay is switched on/off for a specified time in mode 'On for 1.5s and Off for .5s' In case of a Fire Prealarm the relay is switched on/off for a specified time in mode 'On for .5s and Off for 1.5s' In case of an Intrusion Alarm the relay is switched on for a specified time Otherwise the relay is off	Off
13	Fire Output	If the related loop has Fire Alarm or Fire Prealarm status then the relay is switched on, else the relay is switched off (open)	*
14	Trouble Output	If there are related alarm loops having Trouble, Arming Failed, or Disarmed status, the relay is switched off. Otherwise the relay is switched on	*

№	Program	Description	Initial Condition
15	Fire Lamp	In case of a Fire Alarm the relay is switched on/off twice per second in mode 'On for .25s and Off for .25s' In case of a Fire Prealarm the relay is switched on/off once per second in mode 'On for .25s and Off for .75s' In case of a Trouble the relay is switched on/off once per 2 seconds in mode 'On for .25s and Off for 1.75s' If all the alarm loops related with the relay are armed the relay is switched on Otherwise, the relay is switched off	*
16	Alarm Output 2	If all the alarm loops related to the relay are armed or disarmed (that is, there is neither Intruder Alarm, nor Silent Alarm, nor Entrance Alarm, nor Fire Alarm, nor Trouble, nor Arming Failed condition) the relay is switched on, otherwise the relay is switches off	*
17	Switch On For a Time Before Arming	If the related alarm loop is being armed (the Arming Delay has not yet expired) the relay is switched on for a given time	Off
18	Switch Off For a Time Before Arming	If the related alarm loop is being armed (the Arming Delay has not yet expired) the relay is switched off for a given time	On
19	Switch On For a Time Upon Arming	If any related alarm loop has just been armed the relay is switched on for a given time	Off
20	Switch Off For a Time Upon Arming	If any related alarm loop has just been armed the relay is switched off for a given time	On
21	Switch On For a Time Upon Disarming	If any related alarm loop has just been disarmed the relay is switched on for a given time	Off
22	Switch Off For a Time Upon Disarming	If any related alarm loop has just been disarmed the relay is switched off for a given time	On
23	Switch On For a Time When Arming Failed	If arming of any related alarm loop has just failed the relay is switched on for a given time	Off
24	Switch Off For a Time When Arming Failed	If arming of any related alarm loop has just failed the relay is switched off for a given time	On
25	Switch On for a Time Upon Auxiliary Loop Breaking	If there is an Auxiliary Alarm the relay is switched on for a given time	Off
26	Switch Off for a Time Upon Auxiliary Loop Breaking	If there is an Auxiliary Alarm the relay is switched off for a given time	On
27	Switch On Upon Disarming	If at least one related loop is disarmed the relay is switched on	Off
28	Switch Off Upon Disarming	If at least one related loop is disarmed the relay is switched off	On

№	Program	Description	Initial Condition
29	Switch On Upon Arming	If at least one related loop is armed the relay is switched on	Off
30	Switch Off Upon Arming	If at least one related loop is armed the relay is switched off	On
31	Switch On Upon Auxiliary Loop Breaking	In case of an Auxiliary Alarm the relay is switched on	Off
32	Switch Off Upon Auxiliary Loop Breaking	In case of an Auxiliary Alarm the relay is switched off	On
33	ASPT-1	The relay is switched on for a specified time if the alarm loop has got Fire Alarm status and there are no broken Auxiliary alarm loops. If an Auxiliary alarm loop is broken before Relay Activation Delay has not yet expired then, when the loop is recovered, the relay output will be switched on for a specified time. (That is, breaking of the Auxiliary loop temporary blocks activation delay counting.)	Off
34	ASPT-A	The relay is switched on for a specified time if two or more alarm loops related with the output have got Fire Alarm status and there are no broken Auxiliary alarm loops. A broken Auxiliary loop cancels activation the relay, that is, the Auxiliary loop being recovered, the output will NOT be switched on	Off
35	ASPT-A1	The relay is switched on for a specified time if the alarm loop has got Fire Alarm status and there are no broken Auxiliary alarm loops. A broken Auxiliary loop cancels activation the relay, that is, the Auxiliary loop being recovered, the output will NOT be switched on	Off
36	Switch On Upon Temperature Increase	If the alarm loop has got the High Temperature ** status the relay is switched on	Off
37	Switch On Upon Temperature Decrease	If the alarm loop has got the Low Temperature ** status the relay is switched on	Off
NOTES: * The relay behavior is defined by conditions of the group of related alarm loops ** Only that alarm loop which is programmed with the Type 12 (Auxiliary Programmable) can enter High Temperature or Low Temperature condition			

ELECTRONIC KEYS

In order to arm and/or disarm alarm loops of the Signal-10 locally, electronic identifiers (keys) are used which are to be registered in the device memory along with related access rights. For this purpose, an external reader has to be connected to the Signal-10. When a user touches the external reader with an electronic key, the device automatically reads a code of this electronic key and checks its rights for requested operation.

The Signal-10 device enables to read, store in its memory, delete, and change parameters of two different types of keys:

- User Keys
- Master Keys

Key programming procedures are described in details in *Key Programming* Section on the page 82.

User Keys

The User Keys are designed to arm and/or disarm alarm loops. Each User Key can be related with a group of the Signal-10 alarm loops which will be armed and/or disarmed as a whole. The User Key can have the following rights for each alarm loop of the Signal-10:

- arm or disarm
- disarm only
- arm only
- neither arm nor disarm

The combination of rights assigned to a key for each device alarm loop is called *Key Status*.

Controller memory can store 85 User Keys maximum.

Master Keys

Master Keys are designed to switch the Signal-10 to the User Key Programming Mode (see the page 38). This mode enables to add new User Keys or change access rights of existent User Keys by hardware (see *Programming of User Keys by Hardware* Section of this Manual).

A Master Key cannot be used to arm/disarm alarm loops or change other device settings.

OPERATING MODES

The Signal-10 device offers the following modes:

- Pre-Operation Mode
- Operation Mode
- Power Failure Mode
- Output Circuit Failure Mode
- Master Key Programming Mode
- User Key Programming Mode
- Self-Diagnostic Mode
- Device Failure Mode

For description of READY LED operation in different modes of the Signal-10 device, please refer to Table 6.

Table 6. READY LED Behavior in Different Signal-10 Operating Modes

№	Operating mode	LED Behavior
1	Pre-Operation Mode	OFF
2	Operation Mode	Lit with green
3	Master/User Key Programming Mode	Double flashes with green every second
4	Power Failure Mode	Flashes yellow once per second
5	Self-Diagnostic Mode	Flashes red twice per second
6	Device Failure Mode	Flashes red four times per second
7	Output Circuit Failure Mode	Flashes red once per second

Pre-Operation Mode

When supply voltage is applied to power terminals, the device activates and switches to the Pre-Operation Mode. The device power-up time doesn't exceed 3 seconds provided that 11V or higher is available at least at one power input.

Operation Mode

After the Pre-Operation Mode the device switches to the Operation Mode. In the Operation Mode the device provides its main functions, those are alarm loop monitoring, fire alarming, trouble monitoring, built-in relay performance monitoring and control. When used together with the Orion network controller, the Signal-10 also communicates data with the network controller.

Please note, that the device sounds with a melody and the READY LED is switched on with green to enable user to easily recognize that the device has successfully switched to the Operation Mode.

Power Failure Mode

When supply voltage drops below 10V at single or both power inputs, the device switches from a standby condition to the Power Failure Mode. Voltage thresholds for switching to the Power Failure Mode depend on the Both Power Inputs Monitoring setting — see *Signal-10 System Settings* Section of this Manual.

If Both Power Inputs Monitoring is enabled, the device switches to the Power Failure Mode and sends a POWER FAILED message to a network controller when supply voltage drops below 10V at any power input. Once supply voltage at both power inputs becomes higher than 11V, the device recovers the Operation Mode.

If Both Power Inputs Monitoring is disabled, the device maintains the Operation Mode until supply voltage exceeds 10V at any power input. If supply voltage becomes lower than 10V at both power inputs, the device switches the Power Failure Mode and sends the POWER FAILED message to the network controller. Once supply voltage becomes higher than 11V at any power, the device recovers the Operation Mode.

In the Power Failure Mode the device completely retains operation, but READY LED blinks yellow (see Table 6) and the device sounder beeps.

If supply voltage drops below 9V at both power inputs, the device terminates its operation.

If supply voltage increases to 11V at any power input or both power inputs (depending on the Both Power Inputs Monitoring setting), the device automatically switches from the Power Failure Mode to the Operation Mode and generates the POWER RESTORE message.

Output Circuit Failure Mode

When a short circuit or an open circuit occurs between external executive devices and LAM or SIR outputs the device switches to the Output Circuit Failure Mode. In this mode the device completely retains operation, but READY LED blinks red (see Table 6) and the built-in sounder beeps.

The device automatically recovers the Operation Mode after having repaired the failure.

Master Key Programming Mode

This programming mode is intended for service personnel, responsible for the device adjustment and maintenance. To switch the device from the standby condition to the Master Key Programming Mode, press tamper switch with a specific code combination. For detailed description of the Master Key Programming Mode, refer to the *Programming of a Master Key by Hardware* Section on the page 86.

User Key Programming Mode

This programming mode is intended for personnel, responsible for the device adjustment and maintenance. To switch the device from the standby condition to the User Key Programming Mode touch the

device reader with a Master Key. For detailed description of the User Key Programming Mode, refer to the *Programming of User Keys by Hardware* Section on the page 87.

Self-Diagnostic Mode

To switch the device from the standby condition to the Self-Diagnostic Mode, press tamper switch with a specific code combination. For detailed description of the Self-Diagnostic Mode, refer to the *Testing the Signal-10 in Self-Diagnostic Mode* Section on the page 90.

Device Failure Mode

When an error occurs during a microcontroller memory test, the device switches to the Device Failure Mode. The device performs the memory test after each power-up.

When the device switches to the Device Failure Mode:

- READY LED flashes rapidly with red
- Device sounder beeps every 2s
- LEDs '1' – '10' are off
- The device doesn't respond to breaking loops, pressing tamper switch, or presenting electronic keys

If the device switches to the Device Failure Mode after each power-up, update microcontroller firmware. For the firmware update procedure, refer below:

- Forward the corresponding request to ZAO NVP Bolid (remember to specify the device version). Our specialists will respond with dedicated software ("ORION_PROG.EXE") and an electronic file containing the microcontroller firmware.
- Connect the device to a PC via a PI-GR or S2000-PI interface converter.
- Run ORION_PROG.EXE file and apply power to the device.
- Follow on-screen instructions and wait until the firmware update process will be completed. During the firmware update process the device sounder silences and READY LED flashes synchronously with receiving data packages from the PC. The firmware update procedure being completed, the device switches to the Pre-Operation Mode.

FIRE ALARMS

Conventional Fire Alarm Systems

The Signal-10 can operate as a conventional fire control if at least one of its alarm loops is configured with the Type 1, or 2, or 3. For such the loops the device can recognize the following statuses:

- Armed
- Arming Delay
- Arming Failed
- Disarmed
- Fire Signal
- Fire Prealarm
- Fire Alarm
- Trouble

For loops of the Type 12 light indication depends on the type of programmed events.

Sound signaling is provided only for fire and intrusion alarm loops (not for auxiliary loops). The sounder behavior depends on the most dangerous event which is detected by all the device alarm loops.

Table 8 (see the page 51) shows the behavior of the 1 – 10 LEDs of the device which indicates the current statuses of the relative alarm loops, while Table 9 (see the page 52) describes the characteristics of sound signals which are output by the device for some alarm loop statuses.

A fire alarm loop of the Type 1, 2, or 3 is considered to be in *Armed* status if it has been armed and its resistance is within the normal range (see Table 2). Short-timed breaking of armed fire alarm loop of the Type 1, or 2, or 3 within 250 ms doesn't cause the loop status to be considered as a fire alarm.

If a fire alarm loop is programmed with non-zero arming delay, the loop being armed switches to the *Arming Delay* status. Until the Arming Delay has expired, breaking the loop also doesn't cause the loop status to be considered as a fire alarm.

When the Arming Delay has expired and provided that the loop resistance is within the normal range (see above), the loop switches to the Armed status. If, otherwise, the loop resistance is out of normal range, the loop switches to the *Arming Failed* status.

If the Auto Rearming After Failing parameter is set on for the alarm loop, the loop automatically switches from the Arming Failed status to the Armed status after its resistance being in norm for more than 3 s.

If an armed fire alarm loop has been broken for more than 300 ms, the device detects loop breaking and switches the loop to one of the following statuses:

Fire Signal

A smoke (normally open) detector has actuated within a fire alarm loop of the Type 1 or 2

Fire Prealarm	A heat (normally closed) detector has actuated within a fire alarm loop of the Type 2 or 3
Fire Alarm	Two smoke or heat detectors have actuated together within a fire alarm loop of the Type 1 or 3 relatively
Trouble	Short or open circuit failure has occurred within the alarm loop

Alarm loops of the Types 1 and 2 switches from the Armed status to the *Fire Signal* status if a smoke (normally open) detector has actuated within the loop. In such a case the Signal-10 repeatedly queries loop conditions. If the *Fire Loop Requery Prohibition* parameter is set of for this loop, the loop switches to the *Fire Prealarm* status immediately.

Fire alarm loops switch to the Fire Prealarm status either after a single heat detector actuation or after a confirmed smoke detector actuation. The duration of being in the Fire Prealarm status for each alarm loop is defined by the programmed Alarm Delay value. This delay enables analyzing the circumstances and canceling an alarm before generation any signal to start annunciator or automatic fire fighting equipment.

After the termination of the Fire Prealarm status the loop switches to the *Fire Alarm* status. Alarm loops of the Types 1 and 3 can switch from the Fire Prealarm status to the Fire Alarm status before expiration the delay if a second detector has actuated.

If the programmed Alarm Delay is equal to 255, loops of the Type of 1, 3, and 14 switch to the Fire Alarm status only upon two or more detector actuations, while a loop of the Type 2 keeps Fire Prealarm status until the alarm is canceled.

An alarm loop switches from the operation mode to the Fire Alarm status, if either two detectors have actuated for the loops of the Type 1, 3, or 14 or Fire Prealarm status has been terminated. Also, while switching a loop to the Fire Alarm status, the relay related with this loop and programmed with one of executive programs 1...8, 33, or 35 is activated.

If the *Auto Arming After Alarm* parameter is set on for a loop, the loop is automatically armed and switched from the Fire Alarm status to the Arming Delay status when its resistance has been in normal range for more than 15 times the Alarm Delay value in seconds.

An alarm loop switches from Armed status to the *Trouble* status if an open or short failure has been occurred within the loop. If the loop is restored and its resistance has been within the normal range for more than 3 s, the loop is automatically armed.

Addressable Fire Alarm Systems

The Signal-10 can operate as a polling addressable fire alarm device if at least one of its alarm loops is configured with the Type 14 (Fire Threshold Addressable). Bolid manufactured DIP-34PA smoke detectors, or S2000-IP-PA detectors, or IPR513-3PA call points must be included to an alarm loop of the Type 14 (up to 10 initiating devices to each loop). These initiating devices are considered to be addi-

tional addressable zones of the Signal-10. On the contrary to other types of alarm loop, the Signal-10 neither measure resistance values of the alarm loop with the detector included and nor estimate its status. The Signal-10 polls all included (and related to the loops) addressable detectors or call points to generate its generalized statuses (see *Fire Threshold Addressable Alarm Loop (Type 14)* section of this Manual). This generalized status of all related addressable zones of the loop is then displayed by the internal device sounder and the relative LED (as shown in Table 8 and Table 9) as well as initiates relay activation in accordance with the given program and is transmitted to a network controller.

The network controller displays both generalized statuses of the addressable loops and individual statuses of each addressable zone returned by the relevant initiating device and transmitted by the Signal-10 to the network controller.

The *Armed* generalized status for a loop of the Type 14 means that all its addressable zones are armed and has responded with Norm status.

A loop of the Type 14 switches to the *Fire Prealarm* status after actuation of a single smoke detector. The loop is considered to be in Fire Prealarm status until the time given by the Alarm Delay programmed for the loop has expired. This delay enables estimating all the conditions and canceling, if required, initiating external annunciators and automated extinguishing systems.

The loop switches to the *Fire Alarm* status either a second detector in the loop has actuated or until the Alarm Delay has expired. If the Alarm Delay is set as 255 s, the loop can reach the Fire Alarm status only if a second detector in the loop has actuated. Switched to the Fire Alarm status, the loop initiates activation of related relay(s) programmed with the executive programs 1...8, 33, 35.

If the *Auto Arming After Alarm* parameter is set for an alarm loop of the Type 14, the Signal-10 automatically tries to arm its related addressable zones if these zones has responded with Norm status for more than the time period equal to 15 times Alarm Delay in seconds.

INTRUSION ALARMS

The Signal-10 supports generating several different kinds of intrusion alarms depending on the Loop Type setting specified while loop configuring:

- General intrusion alarms (for alarm loops with the Type 4)
- Intrusion and detector tampering alarms (for alarm loops with the Type 5)
- Entrance alarms (for alarm loops with the Type 7)
- Panic alarms (for alarm loops with the Type 11)

For loops of the Type 12 light indication depends on the type of programmed events.

Sound signaling is provided only for fire and intrusion alarm loops (not for auxiliary loops). The sounder behavior depends on the most dangerous event which is detected by all the device alarm loops.

Table 8 (see the page 51) shows the behavior of the 1 – 10 LEDs of the device which indicates the current statuses of the relative alarm loops, while Table 9 (see the page 52) describes the characteristics of sound signals which are output by the device for some alarm loop statuses.

General Intrusion Alarms

The Signal-10 device can operate as an intrusion alarm control if at least one of its alarm loops is configured with the Type 4. For such the loop the device can recognize the following statuses:

- Armed
- Arming Delay
- Arming Failed
- Disarmed
- Intrusion Alarm

An alarm loop of the Type 4 is considered to be in *Armed* status if it has been armed and its resistance is within the normal range (see Table 2. Alarm Loop Resistance Values for Different Loop Statuses’.)

If the alarm loop is configured with the nonzero *Arming Delay* parameter, while being armed this loop has got *Arming Delay* status. If the loop is broken and the delay has not yet expired then no alarms are produced.

When the delay has expired and provided the loop resistance is within the normal range, the alarm loop is considered as *Armed*. Otherwise, if the *Arming Delay* has expired but the loop resistance is outside the normal range then the alarm loop has got the *Arming Failed* status.

If the alarm loop is programmed with the *Auto Rearming After Failing* parameter being set on, it automatically switches from the *Arming Failed* status to the *Armed* status when its resistance has come back to the normal range for at least 3 seconds.

Short-time breaking the armed loop doesn't cause the device to consider the loop condition as an alarm if the time of breaking doesn't exceed:

- 50 ms if the *300-ms Integration Time* parameter is off
- 250 ms if the *300-ms Integration Time* parameter is on

An alarm loop of the Type 4 switches from the Armed status to the *Intrusion Alarm* status if:

- The alarm loop has been broken for more than 70 ms, the *300-ms Integration Time* parameter being off
- The alarm loop has been broken for more than 300 ms, the *300-ms Integration Time* parameter being on
- The loop resistance has jumped by more than 10%, the 10% Deviation Blocking parameter being off for this loop

When the alarm loop has entered the Intrusion Alarm status then relay control in accordance with #1 - #8 executive programs can be activated (if programmed).

If the parameter *Auto Arming After Alarm* is set on for the alarm loop then the loop will be automatically armed and switches from the Intrusion Alarm to the Arming Delay status after its resistance being in the normal range for a time interval more than 15 times value of the Alarm Delay configured for the loop (in seconds).

Intrusion and Detector's Tamper Alarms

The Signal-10 device can operate as an intrusion/detector tampering alarm control if at least one of its alarm loops is configured with the Type 5. For such the loop the device can recognize the following statuses:

- Armed
- Arming Delay
- Arming Failed
- Disarmed
- Intrusion Alarm
- Short Circuit Failure
- Tamper Alarm

An alarm loop of the Type 5 is considered to be in *Armed* status if it has been armed and its resistance is within the normal range (see Table 2). Short-time breaking the armed loop within the time intervals not exceeding:

- 50 ms if the *300-ms Integration Time* parameter is set off
- 250 ms if the *300-ms Integration Time* parameter is set on

doesn't cause the device to consider the loop status as an alarm.

If an alarm loop of Type 5 is configured with the nonzero *Arming Delay*, while being armed this loop initially gets *Arming Delay* status. If the loop is broken but the delay time has not yet expired then no alarms are produced.

When the Alarm Delay has expired and if the loop resistance is within the normal range then the alarm loop is considered as Armed. Otherwise, if the Arming Delay time has expired but the loop resistance is outside the normal range then the alarm loop gets the *Arming Failed* status.

If the alarm loop is programmed with the *Auto Rearming After Failing* parameter being set on, it automatically switches from the Arming Failed status to the Armed status when its resistance has come back to the normal range for at least 3 seconds.

An alarm loop of the Type 5 switches from the Armed status to the *Intrusion Alarm* status if:

- The loop has been broken for more than 70ms, the *300-ms Integration Time* being set off
- The loop has been broken for more than 300ms, the *300-ms Integration Time* being set on
- The loop resistance has jumped by more than 10%, the *10% Deviation Blocking* being disabled

When the alarm loop has entered the Intrusion Alarm status then relay control in accordance with #1 - #8 executive programs can be activated (if programmed).

If the parameter *Auto Arming After Alarm* is set for on the alarm loop then the loop will be automatically armed and switches from the Intrusion Alarm to the Arming Delay status after its resistance being in the normal range for at least the 15 times Alarm Delay value configured for the loop (in seconds).

An alarm loop of the Type 5 switches from the *Disarmed* status to the *Tamper Alarm* status when the contacts of the tamper switch of the detector included into this loop has been opened for more than 300 ms. If then the detector enclosure has been restored and the tamper switch contacts have been closed for more than 15 s, the alarm loop of the Type 5 comes back to the Disarmed status.

An alarm loop of the Type 5 switches from the Disarmed status to the *Short Circuit Failure* status when this failure has happened and held for more than 300 ms. When the failure has been repaired for more than 3 s (the resistance of the loop has been within the normal range) the loop of the Type 5 comes back to the Disarmed status.

Entrance Alarms

The Signal-10 device can operate as an entrance alarm control if at least one of its alarm loops is configured with the Type 7. For such the loop the device can recognize the following statuses:

- Armed
- Arming Delay
- Arming Failed

- Disarmed
- Entrance Alarm
- Intrusion Alarm

An alarm loop of the Type 7 is considered to be in *Armed* status if it has been armed and its resistance is within the normal range (see Table 2). Short-time breaking the armed loop within the time intervals not exceeding:

- 50 ms if the *300-ms Integration Time* parameter is set off
- 250 ms if the *300-ms Integration Time* parameter is set on

doesn't cause the device to consider the loop condition as an alarm.

If an alarm loop of Type 7 is configured with the nonzero *Arming Delay*, while being armed this loop initially gets the *Arming Delay* status. If the loop has been broken but the delay time has not yet expired then no alarms are produced.

When the Alarm Delay has expired and if the loop resistance is within the normal range then the alarm loop is considered as Armed. Otherwise, if the Arming Delay has expired but the loop resistance is outside the normal range then the alarm loop gets the *Arming Failed* status.

If the alarm loop is programmed with the *Auto Rearming After Failing* parameter being set on, it automatically switches from the Arming Failed status to the Armed status when its resistance has come back to the normal range for at least 3 s.

An alarm loop of the Type 7 switches from the Armed status to the *Entrance Alarm* status if:

- The loop has been broken for more than 70 ms, the *300-ms Integration Time* being set off
- The loop has been broken for more than 300 ms, the *300-ms Integration Time* being set on
- The loop resistance jumps by more than 10%, the *10% Deviation Blocking* being disabled

When the loop has switched to the Entrance Alarm status, the *Intrusion/Fire Alarm Delay* starts to be counted. When this delay has expired the loop switches to the *Intrusion Alarm* status.

When the alarm loop has entered the Intrusion Alarm status then relay control in accordance with #1 - #8 executive programs can be activated.

If the *Auto Arming After Alarm* is set on for the alarm loop then the loop will be automatically armed and switches from the Intrusion Alarm to the Arming Delay status after its resistance being in normal range for a time interval more than 15 times value of the Alarm Delay configured for the loop (in seconds).

Panic Alarms

The Signal-10 device can operate as a panic alarm control if at least one of its alarm loops is configured with the Type 11. For such the loop the device can recognize the following statuses:

- Armed
- Arming Delay

- Arming Failed
- Disarmed
- Panic Alarm

An alarm loop of the Type 11 is considered to be in *Armed* status if it has been armed and its resistance is within the normal range (see Table 2). Short-time breaking the armed loop within the time intervals not exceeding:

- 50 ms if the *300-ms Integration Time* parameter is set off
- 250 ms if the *300-ms Integration Time* parameter is set on

doesn't cause the device to consider the loop status as an alarm.

If an alarm loop is configured with the nonzero *Arming Delay*, while being armed this loop initially gets the *Arming Delay* status. If the loop has been broken but the delay time has not yet expired then no alarm is produced.

When the Alarm Delay has expired and if the loop resistance is within the normal range then the alarm loop is considered as Armed. Otherwise, if the Arming Delay has expired but the loop resistance is outside the normal range then the alarm loop gets the *Arming Failed* status.

If the alarm loop is programmed with the *Auto Rearming After Failing* parameter being set on, it automatically switches from the Arming Failed status to the Armed status when its resistance has come back to the normal range for at least 3 s.

An alarm loop of the Type 11 switches from the Armed status to the *Panic Alarm* status if:

- The loop has been broken for more than 70 ms, the *300-ms Integration Time* being set off
- The loop has been broken for more than 300 ms, the *300-ms Integration Time* being set on
- The loop resistance has jumped by more than 10%, the *10% Deviation Blocking* being disabled

The Panic Alarm status of the alarm loop is indicated only by the relative device LED and can activate a relay only if the relay is controlled by the executive program *Alarm Output 1* (#10) or *Alarm Output 2* (#16), with the relay contacts being opened. The device internal sounder doesn't provide any sounds upon a panic alarm.

If the parameter *Auto Arming After Alarm* is set on for the alarm loop then the loop will be automatically armed and switches from the Panic Alarm to the Arming Delay status after its resistance being in normal range for a time interval more than 15 times value of the Alarm Delay configured for the loop (in seconds).

AUXILIARY ALARMS

The Signal-10 device enables monitoring and transmitting to an Orion network controller the conditions of various technological circuits being not directly related to fire and intrusion alarms. Such the circuits involve contacts of devices blocking automated fire-fighting systems, mass sensors, press sensors, flow sensors, throttle valves, liquid level controls and so on.

For these purposes the loops of Type 6 (Auxiliary) and Type 12 (Programmable Auxiliary) are used. Loops of these types can be neither armed nor disarmed: they are *always monitored* by the device, breaking of these loops (that is, *Auxiliary Alarms*) being *always indicated* by the Signal-10 device and transmitted to the network controller.

Auxiliary loops of the Type 6 are considered to be in one of two available statuses, namely the *Auxiliary Zone Alarm* and *Auxiliary Zone Restored* ones. In such a case, if an alarm loop of the Type 6 is matched with any relay output of the Signal-10 (the relevant *Relay ... Control* parameter is on for this loop) breaking of the loop will block activation of the relay controlled in accordance with a given program.

This type of alarm loops is suitable, for example, to block automatic start of a fire-fighting system in the case when a door to the premises is opened.

An alarm loop of the Type 6 switches from the Auxiliary Zone Restored status to the Auxiliary Zone Alarm status if the alarm loop has held broken for at least 300 ms.

Recovering of the broken alarm loop of the Type 6 (that is, switching from the Auxiliary Zone Alarm to the Auxiliary Zone Restored status) is implemented automatically if the resistance of this loop has come to the normal range and is held normal for the time interval equal to Arming Delay parameter programmed for this loop.

Breaking of an alarm loop of the Type 6 causes blocking the relay related with this loop and controlled by the following programs:

- #1...#8 (general purpose programs)
- #11 (ASPT)
- #12 (Siren)
- #33 (ASPT-1)
- #34 (ASPT-A)
- #35 (ASPT-A1)

Blocking of a relay upon breaking of a loop of the Type 6 implies that:

- The relay is not activated if the loop has already been broken
- The relay is returned to an initial condition of the given executive program if the relay was being controlled when the loop has been broken.

The relays controlled by the programs #1...#8, #11 (ASPT) and #33 (ASPT-1) will be activated again after recovering the auxiliary alarm loop, while the relays controlled by the programs #34 (ASPT-A) и #35 (ASPT-A1) will be kept off.

Programmable Auxiliary alarm loops of the Type 12 have 5 available statuses which are defined by user programmable loop resistance threshold values.

If the equipment being in use implies several various conditions and has several output contacts, all these conditions can be monitored by means of a single alarm loop of the Type 12. To do this, all output contacts of the monitored equipment have to be included into the alarm loop along with different additional of shunt resistors. As two special cases, it can consider monitoring circuits for short and open failures.

Figure 1 shows the conditional distribution of available loop statuses and location of the threshold resistances which define these statuses for the particular equipment.




Figure 1. Thresholds of Transition between Different Statuses of Programmable Auxiliary Loops

Threshold values of resistance which define the transition bounds and meaning content of the particular statuses are user programmable.

Signal-10 sound and light indication as well as relay control in case of an alarm loop of the Type 12 are defined by the particular statuses that can be reached by this loop. The statuses are switched only after changing of the loop resistance and are unrelated to other factors or network controller commands. The integration time for changing statuses of an alarm loop of the Type 12 is 300 ms. If the alarm loop of the Type 12 reaches such the status as Armed, Disarmed, Auxiliary Loop Restored or any other 'Restored' the integration time for the status (the time of restoring) is equal to programmed Arming Delay for the loop.

Table 7 shows status codes and statuses which can be programmed for an alarm loop of the Type 12 in the Signal-10 device.

Table 7. Programmable Auxiliary Loops Available Statuses

Status Code	Status	Status Code	Status
1	AC Power Restored	77	Too Low Level
2	AC Power Failed	78	Normal Temperature
3	Intrusion Alarm	82	Heat Sensor Failed
17	Arming Failed	109	Disarmed
24	Armed	118	Entrance Alarm
35	Auxiliary Zone Restored	130	Pump On
36	Auxiliary Zone Alarm	131	Pump Off
37	Fire Alarm	149	Tamper Alarm
38	Auxiliary Zone Alarm-2	152	Tamper Restored
39	Fire Equipment Restored	198	Power Failed
41	Fire Equipment Trouble	199	Power Restored
44	Fire Prealarm	200	Battery Restored
45	Loop Open Failure	202	Battery Failed
58	Panic Alarm	204	Service Required
71	Low Level	206	Low Temperature
72	Normal Level	214	Loop Short Failure
74	High Level	216	Fire Signal
75	Too High Level	220	Gas Press Signal
76	High Temperature	223	Patrol Check

While programming resistance thresholds for statuses of an alarm loop of the Type 12, it needs to know strictly the resistance range for each of the loop status. As it is quite a difficult task, the actual alarm loop resistances can be approximately calculated based on resistance values expressed in ACD units and measured by the Signal-10 device using the formula:

$$R_{\text{loop}} = \frac{281}{ADC} - 1, [\text{K}\Omega],$$

where R_{loop} is the actual resistance value of an alarm loop and

ADC is the ADC-value of the resistance measured by the Signal-10 device.

This formula enables adequately calculating resistance values of the loop ranged from 0.1 KΩ to 50 KΩ. Reading the ADC values is provided either by S2000/S2000M console tools or by UProg Configuration Tool while programming the loop (see Figure 13, the page 75 of this Manual).

LOOP STATUS LIGHT AND SOUND INDICATION

While operating, the Signal-10 device indicates current statuses of all its connected alarm loops by means of its 1 – 10 LEDs and built-in sounder. For loops of the Type 12 light indication depends on the type of programmed events.

Sound signaling is provided only for fire and intrusion alarm loops (not for auxiliary loops). The sounder behavior depends on the most dangerous event which is detected by all the device alarm loops.

Table 8 shows the behavior of the 1 – 10 LEDs of the device indicating the current statuses of the relative alarm loops, while Table 9 (see the page 52) describes the characteristics of sound signals which are output by the device for some alarm loop statuses.

There are two ways the Signal-10 provides light indication for statuses of fire alarm loops (of Types 1, 2, 3, 14), namely its own way and the way which is required by EN-54 standards. The way being in use depends on the current setting of the device system parameter EN-54 (see the *Signal-10 System Settings* section of this Manual).

If the EN54 is disabled, the main statuses of fire alarm loops (that is, Armed, Disarmed, Arming Failed and so on) are indicated by the device LEDs similarly to those of intrusion alarm loops.

If the EN54 parameter is set on (enabled) the statuses of fire alarm loops are displayed as follows:

Armed	The LED is off
Disarmed	The LED is lit steady with yellow
Arming Failed	The LED flashes with yellow
Fire Signal	
Fire Prealarm	The LED flashes with red
Fire Alarm	

For loops of the Type 14 a *generalized* status is indicated (see *Fire Threshold Addressable Alarm Loop (Type 14)* Section of this Manual) by the device LEDs.

For loops of the Type 12 light indication depends on the type of programmed events.

Sound signaling is provided only for fire and intrusion alarm loops (not for auxiliary loops). The sounder behavior depends on the most dangerous event which is detected by all the device alarm loops.

Table 8. 1 – 10 LED Behavior for Different Alarm Loop Statuses

Status of the Loop		Related LED Behavior
Armed, Auxiliary Zone Restored		Lit steady with green
		Off (see the Note below)
Disarmed		Off
		Lit steady with yellow (see the Note below)
Arming Delay	Loop in norm	Flashes with green four times per second
	Loop is broken	Flashes with green four times per second
Arming Failed		Switches on with green for 1s and off for 1s alternately
		Switches on with yellow for 1s and off for 1s alternately (see the Note below)
Fire Signal		Flashes with green and red alternately
		Flashes with red once per second (see the Note below)
Fire Prealarm		Flashes with red once per second
Fire		Flashes with red twice per second
Intrusion Alarm Entrance Alarm Panic Alarm Auxiliary Zone Alarm		Switches on with red for .5s and off for .5s alternately
Tamper Alarm		Flickers with red once per second
Trouble Dusty		Flickers with yellow once per second

NOTE: The behavior is implemented if the EN54 parameter is enabled.

Table 9. The Signal-10 Sounder Behavior Depending on Detected Events

Sound	Signal-10 Alarm Loop Statuses
Continuous two-tone signal	At least one alarm loop has the Fire Alarm status
Interrupted two-tone signal	There are no fire alarms, but at least one alarm loop responds with the Fire Prealarm status
Interrupted single-tone signal	There are neither fire alarms or prealarms, but at least one of the alarm loops of the Types 4, 5, 7 has the Intrusion Alarm status
Rapid interrupted single-tone signal	There are neither fire or intrusion alarms, but one of the loops of the Type 7 has the Entrance Alarm status
Short single-tone signal	There are no alarms responded, but one of the device alarm loops has Failure or Isolated status
Shut off	There are no conditions mentioned above

ALARM LOOP ARMING AND DISARMING

The Signal-10 provides arming and disarming its alarm loops in the following ways:

- locally by presenting a User key to the device reader
- remotely by network controller commands for common or individual alarm loops arming/disarming

Alarm loops of all types can be armed and disarmed, except for loops of Type 6 (Auxiliary alarm loops) and Type 12 (Programmable Auxiliary alarm loops). The conditions of these loops are continuously monitored, a loop breaking always causing an alarm (these loops are always armed). Also, the alarm loops with the Never Disarm attribute set cannot be disarmed.

When making attempt to arm or disarm Auxiliary alarm loops (of Types 6 or 12) or alarm loops with the set Never Disarm parameter, the device sends the current status of these loops to a network controller.

Arming/disarming an alarm loop of Type 14 leads to arming/disarming only for those its addressable zones which are related with the loop by means of *Related Addressable Detectors* parameter (see page 76). The addressable zones, which are not assigned to the loop, don't alter their statuses during arming or disarming Fire Threshold Addressable alarm loops.

Local Arming/Disarming

To arm and/or disarm alarm loops locally, present an electronic identifier registered in the device memory with the respective access rights (a User key) to the device reader. Presenting the key will simultaneously arm (disarm) *all the alarm loops of this device which are associated with this key*.

If the device recognizes the code of the presented identifier, it beeps and the alarms loops associated with this identifier become armed or disarmed. If the read code is unknown to the Signal-10, the device produces long sound tone indicating that the presented key is rejected.

If the presented key offers only privilege to arm loops, it cannot be used to disarm these alarm loops. Such key can only arm the loops again.

If the presented key offers only privilege to disarm loops, it cannot be used to arm these alarm loops but only to disarm the loops again.

Centralized Remote Arming/Disarming

The Signal-10 device enables a network controller to arm/disarm remotely either its individual alarm loops and addressable zones or partitions of the Orion system operating under this network controller.

For centralized arming and/or disarming of separate alarm loops (and addressable zones of threshold addressable initiating devices), the network controller sends commands to the Signal-10 device over the RS-485 interface line.

By means of centralized arming/disarming commands *each addressable zone* of a Fire Threshold Addressable loop of the Signal-10 (loop of Type 14, to which this addressable zone was assigned during the device configuring) *can be armed or disarmed independently* (against local control, see above).

With centralized partition control, codes of electronic identifiers (keys) are written not to the device memory but to the network controller database with relevant access rights (see the Manual for the network controller being in use).

After reading a presented identifier, the device transfers it's code to the network controller over the RS-485 interface. During this process the reader LED flashes red and green alternately (5 flashes per second) until the network controller responses. This process can take from fractions of a second to several seconds depending on the number of devices connected to the RS-485 interface.

If the presented key has privileges to arm/disarm this partition, the reader LED indicates the current status of the partition (Table 10). After presenting this key again the partition is armed, provided that it was disarmed, or it is disarmed otherwise. Each next presenting of the key to a reader leads to the action opposite to the previous one, i.e. if the 2-nd presenting of the key to the reader caused arming of the partition, then the 3-d presenting of the key to the reader will cause disarming of the partition. If the key has limited access rights for the partition, for example, only arming is enabled, this key will always cause arming without regard to a current partition status.

Table 10. Reader LED Indication Depending on Partition Statuses

Partition Status	Reader LED Behavior	Light Color
Disarmed	Off	-
Armed	On	Yellow (Green + Red)
Intrusion Alarm, Fire Alarm, Fire Prealarm, Arming Failed	Flashes twice per second	Yellow
Trouble (in fire partition)	Flashes five times per second	Yellow

If the network controller cannot recognize the presented identifier, or the identifier has no access rights for the partition, or another key is presenting to a reader when the current key is active, then the device rejects access for the key. In such a case the reader LED flashes 3 times followed by the red steady operation.

COMMUNICATIONS BETWEEN THE SIGNAL-10 AND A NETWORK CONTROLLER

The Signal-10 device can operate both standalone (automatically activating relay outputs in accordance with the programmed logic depending on related loop(s) status) and as part of an Orion security system under controlling of a network controller which can be either S2000/S2000M Fire and Alarm Console or a PC with ARM Orion/Orion Pro software installed.

Operating as a part of an Orion system, the Signal-10 maximizes its operability. The Signal-10 transmits to the system all monitored data such as smoke addressable detector conditions, if any, alarm loop statuses, arming/disarming attempts, troubles of the loops, relay outputs, the device itself, and so on. All this information can be output to be observed by an operator or a security administrator, or written into a log for following analysis or reporting, or be output to external indicator modules, or be used within complicated automatic system control scenarios. The Signal-10 operating in on-line mode, its relay outputs can be controlled centrally and remotely (see *Centralized Output Control* section of this Manual), its alarm loop can be centrally remotely armed/disarmed (see *Centralized Remote Arming/Disarming* section of this Manual), as well as current resistance values of alarm loop with all the devices included can be measured remotely (in k Ω or ADC units).

In order to identify the Signal-10 uniquely within an Orion system, a unique network address ranged from 1 to 127 must be assigned to it while programming. This address must coincide with no other device address in the Orion system. The Signal-10 will transmit all the data to the network controller from this address and receive all control commands from the network controller while communicating data over RS-485 interface. The network address can be assigned to the Signal-10 either by network controller tools or by means of UProg.exe configuration tool — see *Signal-10 System Settings* section of this Manual.

For systems with a complicated topology, for example, where RS-485 interface is to be converted into other interfaces intended to be transmitted via local networks, fiber optic, or radio channels, there can be some transmission delays occurring. In such a case a value of the special system parameter Response Pause can be increased to provide proper transmissions (see *Signal-10 System Settings* section of this manual).

Transmitting Messages to a Network Controller

Being connected to an Orion network controller (either S2000/S2000M Fire and Alarm Console or ARM Orion/Orion Pro Workstation), the Signal-10 automatically transmits the network controller messages about its condition and a number of events including changes of loop statuses, relay output conditions, addressable detectors being brought to threshold addressable loops and so on.

All the messages are transmitted over the RS-485 system interface. The data transmission parameters are:

- 9600 Bd
- Half-duplex

If a PC is used as the network controller, it is connected to the RS-485 system interface via one of Bolid manufactured interface converters, namely PI-GR, S2000-PI, USB-RS485, or S2000-USB.

If a communication loss has occurred during generating a message, the event will be stored in the Signal-10 nonvolatile memory. When the communication is restored, the event will be transmitted to the network controller with the time and data specified by the internal Signal-10 clock.

The Signal-10 nonvolatile memory is capable of storing up to 512 last events.

Following is the list of the messages due to the alarm loops of the Types 1-11 or the Signal-10 itself which can be displayed by a S2000M console. Messages displayable by other network controllers (such as a S2000 console, an ARM Orion Workstation, an ARM Orion Pro Workstation) can slightly differ from the messages shown below (see the Manual for the network controller being in use).

ARMED	The alarm loop is armed
ARM FAILED	The loop being armed, the loop resistance was not normal
ARM DELAY	The Arming Delay has not yet expired for the loop
DISARMED	The alarm loop is disarmed
FIRE SIGNAL	A smoke fire detector has actuated within the fire loop
FIRE PREALARM	A heat detector has actuated or actuation of a heat detector is confirmed within the fire loop
FIRE ALARM	Two fire detectors have actuated within the fire loop or the Alarm Delay has been expired
LOOP TRBL OPEN	Open failure has occurred in the alarm loop
RELAY TRBL OPEN	Open failure has occurred in the relay output load circuit
LOOP TRBL SHORT	Short failure has occurred in the alarm loop
RELAY TRBL SHORT	Short failure has occurred in the relay output load circuit
RELAY RESTORE	The relay output load circuit has been repaired
TAMPER ALARM	The enclosure of the device has been opened, or the enclosure of the detector included into the alarm loop of the Type 5 has been opened
TAMPER RESTORE	The enclosure of the device has been closed, or the enclosure of the detector included into the alarm loop of the Type 5 has been closed
TESTING	The self-diagnostic process has been started for the device
PROGRAMMING	The device has been switched to a hardware key programming mode

POWER FAILED	The input power voltage of the device is out of the normal range
POWER RESTORE	The input power voltage of the device has come back to the normal range
ILLEGAL CODE	An unknown electronic key is presented to the Signal-10 reader
USER'S CODE ENTR	A user has presented to the reader an electronic key to arm/disarm alarm loops
AUX ZONE RESTORE	The Auxiliary alarm loop has been restored
AUX ZONE ALARM	The Auxiliary alarm loop is broken
SILENT ALARM	The alarm loop of the Type 11 has been broken
ENTRY ALARM	The alarm loop of the Type 7 is broken, but the Alarm Delay for this loop has not expired
READY TO ARM	The resistance of the disarmed loop is within the normal range
NOT READY TO ARM	The disarmed loop has been broken
INTRUSION ALARM	An intrusion alarm has detected for the loop

In addition to the messages mentioned above, the network controller displays messages due to Programmable Auxiliary alarm loops in accordance with those statuses which were programmed for the loops during configuring (see *Auxiliary Alarms* section of this manual, page 48).

For Fire Threshold Addressable alarm loops, the Signal-10 transmits the network controller both individual condition changes received from addressable detectors or call points and generalized statuses of all addressable zones matched with the loop by the Related Addressable Detectors parameter (see Figure 14).

Following are the list of the individual conditions of addressable detectors and call points which can be displayed by a S2000M console along with the identifiers of its partition, the device, and the addressable zone:

NORM	The detector or call point has responded with the Norm condition
DUSTY	The DIP-34PA detector is dusty and requires a service
TROUBLE	The detector or call point has responded with the Trouble condition
FIRE	The detector has actuated
MANUAL ALARM	The manual call point has been activated
DETECTOR TEST	The detector operability test has been implemented

ISOLATED	The detector or call point has not responded for more than 10 s
CONNECTED	A response has been received from the addressable detector or call point which was isolated before

Following is the list of available generalized statuses of alarm loops of the Type 14 displayable by a S2000M console along with identifiers of the partition, the device, and the loop:

FIRE ALARM	Two or more loop addressable zones have the Fire Alarm status, or the Alarm Delay given for this loop has been expired
FIRE PREALARM	There is at least one addressable zone in the Fire Alarm status
TROUBLE	There is an addressable zone with the Trouble status, and there is no zone with the Fire Alarm status
ISOLATED	There is an isolated addressable zone in the loop, while there are no zones with Fire Alarm or Trouble statuses
FIRE SIGNAL	There is an addressable zone with Test status and there are no zones with Isolated, Trouble, or Fire Prealarm, or Fire Alarm statuses
ARM FAILED	At the moment of arming, one of the addressable zones of the loop has a not Norm status, no other zones having more priority statuses (said above)
ARM DELAY	The transient status when after an attempt to arm an addressable zone the response from the addressable detector is waiting for, and there are no zones with more priority statuses (said above)
SERVICE REQUIRED	There is an addressable zone with the Dusty status, all other zones being in Norm
DISARMED	There is a disarmed addressable zone within the loop, all other zones of the loop being armed
ARMED	All addressable zones are in norm and armed

INSTALLATION



STANDARD DELIVERY

Find the following when unpacking the Signal-10 device:

- Signal-10 Intrusion and Fire Alarm Panel
- Information Disk
- 4.7 kOhm Terminating Resistors (10)
- Woodscrews (3)
- Wall Plugs (3)
- DIN 7982 Flat Head Tapping Screw with Cross Drive 2,2x6,5

NOTE: *Readers such as Schityvatel-3 or similar and DS1990A iButtons are not supplied with the Signal-10 and should be ordered separately.*

SAFETY PRECAUTIONS



There are no potential hazard circuits within the Signal-10

Do SHUT OFF the device power before mounting, wiring, or maintaining the Signal-10

Mounting and maintenance the device must be implemented by qualified engineers

SIGNAL-10 MOUNTING

Figure 2 shows the view of the Signal-10 along with its overall and mounting dimensions.

The device can be installed in boxes, on walls and other constructions in premises which are protected against atmospheric fallouts and mechanical damage. Being installed in insecure premises, the device must be attached at a height of at least 2.2 m above the floor.

Mount the device in accordance with the Signal-10 connection diagram shown in Figure 3.




Figure 2. Signal-10 Overall and Mounting Dimensions

WIRING THE RS-485 INTERFACE LINE

Connect the Signal-10 to an Orion network controller via RS-485 interface by doing the following:

1. Couple the device terminals RS485A and RS485B (see Figure 3) with A and B wires of RS-485 bus respectively.
2. Couple the 0V circuit of the Signal-10 device (see Figure 3) with the similar circuits of the preceding and succeeding devices in RS-485 highway (you can ignore this requirement if the devices are powered by the same power supply).
3. If the Signal-10 is *neither the first nor the last device* within RS-485 highway, remove the jumper that is located closely to the RS485A and RS485B contacts on the device PCB. (This jumper, if put on, includes the EOL resistance of 620 Ω into the RS-485 interface line.)

While mounting the RS-485 interface line, it is advisable to implement the *bus* network topology (that is, connect the devices in a chain). If a long-distance branch (more than 50 m from the RS-485 bus) needs to be realized, a Bolid S2000-PI interface repeater is to be included at the cross point. It can be brought up to 10 S2000-PI interface repeaters in a single RS-485 bus segment (up to 10 branches can be made). The number of successively included repeaters is not limited.

CONNECTING EXTERNAL DEVICES TO THE DEVICE OUTPUTS

The SIR and LAM output terminals of the Signal-10 are designed to wire external sound and light alarms respectively.

Following are some variants of connecting external devices to the SIR and LAM output terminals of the Signal-10 (see Figure 3):

Var.1 is for sound and light alarms with high internal resistance (more than 10 k Ω) and low operating current (less than 2.5 mA) such as piezoelectric sirens and single light electric diodes.

Var.2 is for sound and light alarms with high internal resistance (more than 10 k Ω) such as light tables, for example.

Var.3 is for sound and light alarms which internal resistance ranges from 26 Ω to 10 k Ω .

If SIR or LAM output is not in use (no sound or light alarms are to be connected to the device) terminate it with a resistor of 1.0 to 8.2 k Ω , 0.25 W.




Figure 3. Signal-10 Connection Diagram

CONNECTING ALARM LOOPS

Any fire / intrusion detectors intended to be powered by a DC power supply can be included into the Signal-10 alarm loops provided that fire detectors have the values of internal resistance at Fire mode no more than $2.7 \text{ k}\Omega$ for normally open detectors and at least $3.2 \text{ k}\Omega$ for normally closed detectors.

An intrusion alarm loop must meet the following requirements:


- The wire resistance without regard to termination resistor must not exceed $1 \text{ k}\Omega$
- The leakage resistance between loop wires or between each wire and the earth must be at least $20 \text{ k}\Omega$

A fire alarm loop must meet the following requirements:

- The wire resistance without regard to termination resistor must not exceed 100Ω
- The leakage resistance between loop wires or between each wire and the earth must be at least $50 \text{ k}\Omega$

Following are some examples for including various detectors into alarm loops of different types.

Including Detectors into Fire Smoke Alarm Loops of the Type 1



D1: A smoke detector

Ra: An additional resistance of $1.5 \div 2.4 \text{ k}\Omega$

Rt: $4.7 \text{ k}\Omega$

Figure 4. Detectors into a Fire Loop of the Type 1 Connecting Diagram

When all the detectors will be wired and connected to the relative Signal-10 contacts, test the loop. Ensure that confirmed actuation of a single detector causes the loop to get the Fire Prealarm status, while actuation of two ones causes the loop to get the Fire Alarm status. Light and sound indication of the Signal-10 device must be in accordance with that described in Table 8. The network controller must display the relative messages from the Signal-10 device (see *Transmitting Messages to a Network Controller* section of this Manual).

Otherwise, if the test fails, the values of additional resistances have to be corrected.

Including Smoke and Heat Detectors into Alarm Loops of the Type 2




Figure 5. Smoke and Heat Detectors into a Fire Loop of the Type 2 Connecting Diagram

When all the detectors are wired and connected to the relative Signal-10 inputs, test the loop. Ensure that confirmed actuation of a single smoke detector or actuation of a heat detector causes the loop to get the Fire Prealarm status, while actuation of two detectors (smoke or heat) causes the loop to get the Fire Alarm status. Light and sound indication of the Signal-10 device must be in accordance with that described in Table 8. The network controller must display the relative messages from the Signal-10 device (see *Transmitting Messages to a Network Controller* section of this Manual).

Otherwise, if the test fails, the values of additional resistances have to be corrected.

Including Heat Detectors into Alarm Loops of the Type 3




Figure 6. Heat Detectors into a Fire Loop of the Type 3 Connecting Diagram

Including Intrusion Detectors into Alarm Loops of the Type 4




Figure 7. Wiring Intruder Detectors into Alarm Loops of the Type 4

Including Intrusion Detectors into Alarm Loops of the Type 5




Figure 8. Wiring an Intruder Detector into Alarm Loops of the Type 5




Figure 9. Wiring a Foton-SK Intruder Detector into Alarm Loops of the Type 5

Wiring Initiating Devices into Alarm Loops of the Type 14

Up to 10 Bolid manufactured DIP-34PA detectors, or S2000-IP-PA detectors, or IPR513-3PA manual call points can be connected to a single Signal-10 alarm input. The own address of each initiating device is set from 1 to 10 before installation (in accordance with its Manual) and is stored in the initiating device memory.

NOTE: DO NOT include two or more initiating devices with the same own addresses into an alarm loop of the Type 14

CONNECTING POWER SUPPLIES

The Signal-10 is designed to be powered by one or two power supplies of 12-24 V. It is advisable to use uninterrupted power supplies of RIP-12 or RIP-24 series manufactured by the Bolid Company. If external sound and light alarms are to be connected to the device outputs SIR and LAM and the commuting parameters of these alarms are close to maximum provided by the Signal-10 (see *Specifications* section of this Manual), then it is advisable to power the Signal-10 by a 24 V supply.

If two power supplies are connected to the Signal-10, then the way for the device to switch to the Power Failure Mode (see *Power Failure Mode* Section of this Manual) depends on current setting of the *Both Power Inputs Monitoring* parameter. This parameter defines whether the device indicates a power failure when power voltage is low for a single power input or both power inputs (see *Signal-10 System Settings* section of this Manual).

COMMISSIONING

During the process of commissioning and starting-up the particular security installation it can be necessary to measure actual resistance values of alarm loops along with detector included. It can be done either by tools of a network controller (see *Alarm Loop Inspection* section of this Manual, page 91) or by means of UProg configuration program which is installed on a PC connected to the Signal-10 via one of the Bolid manufactured interface converters (it can be a PI-GR, S2000-PI, S2000-USB, or USB-RS485).

To measure a current resistance value of the alarm loops connected to the Signal-10 by means of UProg, select *Alarm Loops* tab and click on the splitter button at the centre of the right window bound. The *ADC Values* pane will be expanded (see Figure 10). Press on the Read Button, and the Signal-10 will display the measured resistance values in ADC units for all the alarm loops that are connected to the device.

To collapse ADC Values pane toggle the splitter button once more.




Figure 10. Measuring Alarm Loop Resistances by Means of UProg

PROGRAMMING




Programming the Signal-10 device for specific operations is implemented by setting or changing its configuration parameters stored in the device non-volatile memory. To do this the Signal-10 device is to be connected via one of the interface converters (PI-GR, S2000-PI, S2000-USB, or USB-RS485) to a PC which is equipped with the program for configuring Orion system devices, **UProg.exe**.

After starting the program its main window will be output on the PC display. The UProg menu and its toolbar are located at the top area of the window.

Select the *Device* → *Read Device Configuration* command (or press <Ctrl+F3>, or select  icon from the toolbar). The Device Search window will be output to the display. Specify the number of the logic COM port the Signal-10 is connecting to, and the UProg.exe will find all the devices connected to that COM port of the PC. Then the list of all found devices along with their network addresses and version numbers will be shown at the display.

Select the entry for the Signal-10 and press the *Select* button. The UProg will display the work window of the current Signal-10 settings. All the settings are presented by three tabs which are the Alarm Loops, the Outputs, and the Keys tabs (see Figure 11).



	LP1	LP2	LP3	LP4	LP5	LP6	LP7	LP8	LP9	LP10
Loop Type	1	1	1	1	1	1	1	1	1	1
Alarm Delay, s	0	0	0	0	0	0	0	0	0	0
Arming Delay, s	0	0	0	0	0	0	0	0	0	0
Loop Analysis Delay, s	0	0	0	0	0	0	0	0	0	0
Activation Delay for Relay 1, s	0	0	0	0	0	0	0	0	0	0
Activation Delay for Relay 2, s	0	0	0	0	0	0	0	0	0	0
Activation Delay for Relay 3, s	0	0	0	0	0	0	0	0	0	0
Activation Delay for Relay 4, s	0	0	0	0	0	0	0	0	0	0
Never Disarm										
Auto Rearming After Failing	+	+	+	+	+	+	+	+	+	+
Auto Arming After Alarm										
Disarmed Loop Monitoring										
Fire Loop Requery Prohibition										
300-ms Integration Time	+	+	+	+	+	+	+	+	+	+
10% Deviation Blocking										
Relay 1 (Alarm 1) Control										
Relay 2 (Alarm 2) Control										
Relay 3 (Siren) Control										
Relay 4 (Lamp) Control										

Figure 11. UProg Work Window for Configuring the Signal-10

You can also get an access to the device settings by loading its configuration from a file at any storage medium with the help of the *File → Load Configuration File* command (or the <F3> button, or the



toolbar icon).

Besides, a new Signal-10 configuration file can be created by using the *File → New Configuration* menu command (or the <Ctrl+N> button, or the  toolbar icon).

The newly created or revised configuration can be:

Loaded to the device memory



, or *Device → Write Configuration to This Device*

Loaded to another connected Signal-10 device with its network address specified

Device → Write Configuration to Another Device

Saved to a file of the internal UProg format with the *.cnu* extension



, or <F2>, or *File → Save Configuration to File*

Written as a text to a MS Word file



, or *File → Export Configuration to MS Word*

SIGNAL-10 SYSTEM SETTINGS

The system configuration parameters of the Signal-10 define its specific operation features and gives its network settings while working as a part of an Orion security system. The device system configuration parameters are shown in Table 11.

Table 11. Device Configuration Parameters

Parameter	Description	Value Range	Factory Value
Both Power Inputs Monitoring	Defines the condition upon which the device will switch to the Power Failure mode: upon a both power inputs failure or upon a single input failure	On / Off	Off
EN54	Provides indicating fire alarm loop statuses in accordance with EN54-2 standard requirements	On / Off	Off
Network Address	Defines the device network address within a RS-485 highway	1 ... 127	127
Response Pause	Defines the admissible delay for the device responding to a network controller request	From 1.5 ms to 500 ms incremented by 0.125 ms	1.5 ms

The **Both Power Inputs Monitoring** parameter defines the conditions for the Signal-10 to switch to the Power Failure mode: upon a power failure of a single input or both power inputs. If Both Power Inputs Monitoring is set on, the Signal-10 switches to the Power Failure mode (see *Power Failure Mode* section of this Manual) when power input voltage has dropped below 10 V at any single power input. The device will come back to the Operation mode when the voltage has been more above 11 V at both power inputs.

If Both Power Inputs Monitoring parameter is set off, the device keeps the Operation mode still the power voltage exceeds 10 V at least at a single power input and switches to the Power Failure mode if the power voltage has dropped below this value. The device returns to the Operation mode when the power voltage of at least one power input has reached to 11 V.



To set on/off the **Both Power Inputs Monitoring** parameter, tick by left mouse click the similarly-named box located below the toolbar at the Alarm Loops tab

The **EN54** parameter defines the way for fire alarm loop (of the Types 1, 2, 3, and 14) statuses to be displayed by the relevant device indicators. If the parameter is set off, displaying such main statuses as Armed, Disarmed, Arming Failed and so on for fire alarm loops is similarly to that for intrusion alarm loops.

If the EN54 parameter is set on, statuses of fire alarm loops are displayed by the following way (see *Loop Status Light and Sound* section of this Manual):

- To display Armed status the related LED is off
- To display Disarmed status the related LED is lit yellow
- To display Arming Failed status the related LED is flashing yellow
- To display alarm statuses such as Fire Signal, Fire Prealarm, or Fire Alarm, the related LED is flashing red



To set on/off the **EN54** parameter, tick by left mouse click the similarly-named box located below the toolbar at the Alarm Loops tab

The **Network Address** parameter is intended for unique identification of the device as a specific part of an Orion system. The Signal-10 transmits messages from and receives network address commands at the address defined by this parameter. The Network Address value must be unique for each the device connected to an Orion network controller.



To define or change the **Network Address** of the device, select the *Device → Change Device Address* command from the UProg main menu.

The network address of the device can also be set or changed by means of network controller tools in accordance with the Manual for the network controller being in use.

Setting the **Response Pause** parameter provides using the device within a system with a sophisticated network topology where long layover can be, for example, while converting RS-485 data into other interfaces intended for transmission over local area networks, fiber optic channels, or radio channels.



To set or change the **Response Pause** value, select the *Device → Set Response Pause* command from the UProg menu.

The current values of the Network Address and Response Pause can be reset to factory (default) values by pressing the device tamper switch with special way: long–long–long–short. ‘Long pressing’ means pressing and holding the tamper switch pressed for more than 1.5 s, while ‘short’ one means pressing and holding the tamper switch pressed for the time between 0.1 s to 0.5 s. The pause between pressings must last from 0.1 s to 0.5 s.

ALARM LOOP PROGRAMMING

In order to program alarm loops of the Signal-10, select the Alarm Loops tab of the UProg Configuration Tool. All available parameters are shown placed in a table (see Figure 12).

	LP1	LP2	LP3	LP4	LP5	LP6	LP7	LP8	LP9	LP10
Loop Type	1	1 - 		1	1	1	1	1	1	1
Alarm Delay, s	0	1 - Fire Smoke 2 - Fire Combined 3 - Fire Heat 4 - Intrusion 5 - Intrusion With Tamper Monitoring 6 - Auxiliary 7 - Entrance 11 - Alarm 12 - Auxiliary Programmable 14 - Fire Threshold Addressable								
Arming Delay, s	0									
Loop Analysis Delay, s	0									
Activation Delay for Relay 1, s	0									
Activation Delay for Relay 2, s	0									
Activation Delay for Relay 3, s	0									
Activation Delay for Relay 4, s	0									
Never Disarm		0	0	0	0	0	0	0	0	0
Auto Rearming After Failing	+	+	+	+	+	+	+	+	+	+
Auto Arming After Alarm										
Disarmed Loop Monitoring										
Fire Loop Requery Prohibition										
300-ms Integration Time	+	+	+	+	+	+	+	+	+	+
10% Deviation Blocking										
Relay 1 (Alarm 1) Control										
Relay 2 (Alarm 2) Control										
Relay 3 (Siren) Control										
Relay 4 (Lamp) Control										

Figure 12. Alarm Loop Programming

Loop Type Adjusting

The main parameter which must be given for each of the connected alarm loop is the **Loop Type**, which is by default set to '4' for all the Signal-10 loops. All available Loop Type values are described in the *Alarm Loop Types* section of this Manual.

To define the Loop Type value, double click by left mouse button on the cell which is located at the intersection of Loop Type string and the column related to a required alarm loop. Then select a proper value from the drop-down list (see Figure 12).

If you are programming a loop of the Type 12 or a loop of the Type 14 an additional pane will appear at the right part of the UProg window.

While programming a loop of the Type 12, a Programmable Auxiliary alarm loop, the *Additional Properties* pane (see Figure 13) is output at the display in order to program all the statuses and transition thresholds between them as described in the *Programmable Auxiliary Alarm Loop (Type 12)* section of this Manual.

Additional Properties

Status I: -

I to II Status Res: -
 AC Power Restored
 AC Power Failed
 Intrusion Alarm
 Arming Failed
 Armed
 Auxiliary Zone Restored
 Auxiliary Zone Alarm

Status II: -

II to III Status Res: 0 >50 kOhm, 27 V

Status III: -

III to IV Status Resistance Threshold: 0 >50 kOhm, 27 V

Status IV: -

IV to V Status Resistance Threshold: 55 3.9kOhm, 21.4V

Status V: -

ADC Reading

Read

Figure 13. Programming Statuses and Transition Thresholds for Alarm Loops of the Type 12

Each status is to be selected from a drop-down list (see Figure 13.), the transition thresholds between them being programmed in ADC units ranged from 0 to 255. As far as an ACD value is typed or selected by narrow buttons, an approximate loop resistance value in kΩ is appeared at the next field at the right.

Practically, it is too difficult to know which loop resistance value can match to a particular loop status. Thus, the UProg facilitates this task by the special actual resistance measuring tool. To measure the resistance of an alarm loop connected to the Signal-10 along with included devices being in a particular condition, press the *Read* button located in the *ADC Reading* field. The value measured in ADC units can be converted to a value expressed in kΩ by using the formula:

$$R_{lp} = \frac{281}{ADC} - 1, [\text{kohm}],$$

where R_{lp} is the alarm loop resistance value;

ADC is the ADC value measured by the Signal-10

The formula provides adequate calculating of actual resistance values ranged from 0.1 kΩ to 50 kΩ. You can also read ADC values by means of S000M/S2000 console tools.

While programming a loop of the Type 14, Fire Threshold Addressable alarm loop, the *Related Addressable Detectors* pane (see Figure 14) is output at the display in order to match own addresses of

addressable initiating devices to be included into the loop to the relevant addressable zones of the loop.

Related Addressable Detectors

☐ Address 1	☐ Address 9
☐ Address 2	☐ Address 10
☐ Address 3	
☐ Address 4	
☐ Address 5	
☐ Address 6	
☐ Address 7	
☐ Address 8	

Figure 14. Matching the Own Addresses of Initiating Devices to an Alarm Loop of the Type 14

Addressable initiating devices DIP-34PA, S2000-IP-PA, IPR513-3PA have its own addresses ranged from 1 to 10 which are stored in their non-volatile memory. Each detector or call point must be related to an addressable zone of the configured loop with the address which coincides with the detector or call point address. To do this, tick the relevant box by left mouse button. If matching of an initiating device address to the same addressed addressable zone is missed, this zone doesn't take part upon generation generalized loop statuses and is not affected by arming/disarming commands (see the *Fire Threshold Addressable Alarm Loop (Type 14)* section of this Manual).

Other Loop Parameters Adjusting

This section describes adjusting the parameters which were discussed in the *Alarm Loop Types* section of this Manual. Turning these parameters on/off is implemented by double click of the left mouse on the cell which is located at the intersection between the corresponding parameter string and the loop column.

Alarm Delay

For fire alarm loops of types 1, 2, 3, 14 this parameter means a time-out for transition from the Fire Prealarm status to the Fire Alarm status, while for an Entrance loop (a loop of the Type 7) it means the delay for transition from the Entrance Alarm status to the Intrusion Alarm status (that is, the entry delay). The delay setting in zero (by default for all the loops) means that the loop will switch to Fire/Intrusion Alarm immediately without any delay, while setting to 255 means the infinite delay.

Arming Delay

The Arming Delay parameter is by default set to zero for all the alarm loops of the Signal-10. This parameter is set to a non-zero value typically for Entrance alarm loops to define for the Signal-10 a time interval (in seconds) between receiving an arming command and actual arming the alarm loop (that is, the exit delay). Moreover, if a relay of the Signal-10 must be activated before arming a loop,

for example, to unset power of four-wire detectors (by means of the *Switch On For a Time Before Arming* executive program), the alarm loop MUST be programmed with a non-zero Arming Delay value.

Loop Analysis Delay

The Loop Analysis Delay for an alarm loop of any type defines the duration of a pause between starting powering the loop and analyzing its conditions. This delay enables including into alarm loops the detectors with high warm-up times (settling times). For such the detectors the Loop Analysis Delay must be set to a value slightly exceeding the maximum readiness time.

The minimum hardware delay is 1 s (the default value). This value can be increased up to 63 s.

Activation Delay for Relay 1 - Activation Delay for Relay 4

If changing the statuses of the given alarm loop must cause one of the device relay outputs to be activated (see *Relay ... Control* parameters below), the relay can be activated not immediately but after a time given by the *Activation Delay for Relay ...* parameter (from 0 s to 255 s).

NOTE: If the following executive programs are given for a relay (see Table 5):
9 (*Lamp*),
10 (*Alarm Output 1*),
13 (*Fire Output*),
14 (*Trouble Output*),
15 (*Fire Lamp*), and
16 (*Alarm Output 2*),
then *this parameter setting is ignored*, the output being activated immediately after changing a status of the programmed alarm loop.

By default, activation delays are equal to zeros for all the alarm loops.

Never Disarmed

This parameter is set off by default and should be set on when disarming of an alarm loop (either accidental or intentional) is inadmissible.

Auto Rearming After Failing

By default, an alarm loop is automatically armed when it is in the Arming Failed mode and its resistance keeps the normal value for more than 3 s. To prohibit an alarm loop to be automatically armed, turn this parameter off for this loop.

Auto Arming After Alarm

If this parameter is turned off for an alarm loop, the alarm loop automatically switches from the Intrusion Alarm, Panic Alarm, or Fire Alarm status to the Armed status if loop resistance has been within

the normal range for more than 15 times Alarm Delay value in seconds. By default this parameter is off.

Disarmed Loop Monitoring

If this parameter is set on for an alarm loop (by default it is set off for all the device alarm loops), then breaking of this loop being in the Disarmed status will be transmitted to a network controller.

Fire Loop Requery Prohibition

This parameter disables the function of repeated query (or verification) for statuses of alarm loops of the Types 1 and 2 when a fire detector has actuated. If the Fire Loop Requery Prohibition is set on, then a single actuation of a smoke detector will switch the alarm loop to the Fire Prealarm status.

By default this parameter is set off, that is, after a single smoke detector actuation the device generates a Fire Signal message and queries the loop status once more. If within 55 s the detector actuates repeatedly, the alarm loop switches to the Fire Prealarm status, otherwise it returns to the Armed status.

300-ms Integration Time

This parameter enables to set the integration time for the intrusion alarm loops (of the Types 4, 5, 7, 11). 'On' value (it is the default value) means the integration time of 300 s, while 'Off' value means the integration time of 70 ms. In order to avoid false alarms, turn this parameter off only when it is strictly necessary.

10% Deviation Blocking

The parameter disables for intrusion alarm loops the analysis of sharp deviations of alarm loop resistance values (more than by 10% of a steady value), however staying within the normal range. It is advisable to set this parameter on for such alarm loops which involves detectors causing high voltage ripples (the parameter is set off by default).

Relay 1 Control – Relay 4 Control

These parameters must be set on for those loops which condition altering is to lead to activation of the relevant relay output.

NOTE: If a relay output is intended to be controlled centrally, by network controller commands, then this parameter *MUST be set off for all the alarm loops* of the Signal-10.

By default, the relay 1 is related to conditions of the Signal-10 alarm inputs from the first to the fifth, while the relay 2 is related to conditions of the Signal-10 alarm inputs from the sixth to the tenth. Outputs 3 and 4 (The Siren and the Lamp) are related by default to all alarm loops of the Signal-10.

PROGRAMMING OUTPUTS

To program the Signal-10 relay outputs, use Outputs Tab of the UProg Configuration Tool (see Figure 15).

If one of the device relays is to be centrally-controlled by network controller commands than this relay must not be related with any device alarm loop (the relative Relay...Control parameter must be set off for all the device alarm loops — see above).

If, otherwise, a relay is to be controlled locally depending on the device alarm loop statuses, the relay must be related to the relevant alarm loops via the relative Relay...Control parameter. Moreover, a relay activation delay can be specified at the Alarm Loops tab — see the previous section.

NOTE: If a relay is assigned to an alarm loop (loops) then control commands of a network controller via RS-485 highway will be ignored. *Local relay control is more priority than centralized one.*




Figure 15. Signal-10 Relay Outputs Programming

The following parameters must be specified for all of the Signal-10 relay outputs:

Executive Program

The Executive Program defines the tactics of relay control which is implemented locally (depending on the Signal-10 alarm loop statuses) as well as initial condition of the relay right after Signal-10 power up.

To give a local control program for each the relays 1 – 4, click by left mouse button on the narrow button at the right of the relevant field and select a proper program from the drop-down list (see Figure 15).

If the relay is to be controlled centrally select such a program which implies the proper initial condition of the relay output after device powering-up ('On' or 'Off').

All available executive programs are listed in Table 5 on the page 32 of this Manual.

By default, the solid state relays 1 and 2 are programmed with the executive program #10 (*Alarm Output 1*), the relay 3 is assigned with the program #12 (*Siren*), and the relay 4 is assigned to the program #9 (*Lamp*).

Relay Activation Time

The Relay Activation Time parameter defines a time interval during which a relay output is being activated for those executive programs which imply the limited activation times.

Select a proper time value by means of narrow buttons at the right of the relevant field at the Outputs tab. The maximum activation time for each relay is 65 535 intervals of 0.125 s each (8192 s total). By default the relay 3 (Siren) is being activated for 2 minutes (or 120 s), while for another relays the maximum activation time of 8192 s (approximately two hours) is specified.

In the case of centralized control this setting is ignored.

Monitor for

This parameter is to be given only for transistor relay outputs 3 and 4. It defines which troubles of an external load circuit connected to the output will be monitored for by the Signal-10. The trouble conditions are monitored permanently, without regard to is the output activated at the moment or not.

In order to specify the kind of monitored troubles for the load circuits of the outputs 3 and 4, click by the left mouse button on the narrow button at the right of the relevant field and select a proper value from the drop-down list:

1 – Without Control	The external load circuit connected to the output is not monitored for troubles
2 – Open Failure	The external load circuit connected to the output is monitored for open circuit failures

3 – Short Failure	The external load circuit connected to the output is monitored for short circuit failures
4 – Open and Short Failure	The external load circuit connected to the output is monitored for open and short circuit failures

By default, for relay outputs 3 and 4 the maximum level of trouble monitoring is set (the Monitor For parameter is set to 4).

Relay ON/OFF Events

The Relay ON/OFF Events parameter can be set on individually for each relay output. If the parameter is set on then alterations of output conditions are transmitted to a network controller. By default this parameter is set off.

When all settings are completed, don't remember to save them by loading to the device memory (using the  toolbar icon or *Device → Write Configuration to This Device* menu command).

KEY PROGRAMMING

If Signal-10 protection zones (that is, alarm loops and addressable zones of loops of the Type 14) are intended to be armed/disarmed locally, it is necessary to record to the Signal-10 memory codes of all the keys which will be used and to program its attributes. In the case of centralized control key codes are recorded to the database of a network controller instead of the Signal-10 memory.

The Signal-10 memory is designed to store up to 85 key codes, which can be codes both of User keys (intended to arm/disarm alarm loops) and Master keys (used for hardware programming other keys).

Keys can be programmed both by software using UProg.exe and by hardware.

Key Programming by Means of UProg.exe

To program keys by means of the UProg Configuration Tool select its Keys tab (see Figure 16). The left part of the window will display the list of programmed keys. Below the list the total number of programmed key and the maximum available number of keys (that is, 85 ones) are pointed.

Keys tab of the UProg has its own toolbar:



- Export Key Codes: This tool enables writing all the keys listed at the left part of the window to a text file or MS Word file. If keys are written to an MS Word file, the keys are written along with all programmed attributes, while if keys are written to a text file, only key codes, names and order number in the list are recorded



- Read Keys from File: This tool works like the similar File menu command. The command enables loading to the UProg.exe key codes and attributes from a storage medium in order to change their descriptors and/or load them to the device memory



- Save Keys to File: This tool works like the similarly command from the File menu. The command enables writing codes and attributes of the keys displayed at the left of the window to a special file (to any storage medium). This file then can be used to facilitate adjusting other devices



- Read Keys from Memory: The tool provides loading to the UProg.exe the list of keys which are stored in the memory of the Signal-10 connected currently to the PC



- Write Keys to Memory: The tool enables writing all key codes and attributes shown at the left part of the window to the memory of the Signal-10 device connected to the PC



- Add Key: The tool adds a new descriptor to the list of keys (the same can be done by pressing <Ins>)



- Delete/Restore Key: This tool 'deletes' and restores keys from the key list (the same can be done by pressing). It marks a key as deleted, but the Key is not physically cleared from the device memory and can be restored (see below)



- Find Key Duplicates: This tool enables finding descriptors of all the keys that have the same code



- Clear Keys: Physically deletes all keys from the device memory



- Defragment Key Memory: The tool defragments the key area of the Signal-10 memory by clearing the keys marked as deleted followed by rearranging the key order in the list. During defragmentation process the keys marked as deleted are replaced with the legal keys, so after the defragmentation the numbers of the key descriptors are varied



- Show Deleted Keys: This switch defines whether the keys marked as deleted are visible in the key list or hidden. If the switch is on (the button is sunken), the keys marked as deleted are displayed in grey color and can be restored by pressing Delete/Restore Key button or button. If the switch is off, only active keys are shown in the list



- Find Key: Finds a key descriptor by the given code of the key




Figure 16. Programming Electronic Keys by UProg.exe

The UProg.exe provides adding keys to the Signal-10 memory as well as deleting them and editing their attributes.

Add/Edit a Key

NOTE: In order to handle keys correctly, ALWAYS LOAD THE EXISTING KEYS FROM THE SIGNAL-10 MEMORY (IF PRESENTED) BEFORE ADDING NEW KEYS. Otherwise, if you have added some new keys and are trying to save changes, all the keys stored at the device memory will be lost.

There are two ways to add keys:

- To read keys from a special file by means of  icon, and
- To create new key descriptors by means of  icon or *<Ins>* key pressing

In last case to add a key:

- 1) Press Add Key button (or *<Ins>*); the new entry named as 'New Key' will appear in the key list
- 2) Describe the reader which the key being registered will be presented to. To do this specify in the boxes located below the key list the network address of an Orion system which the reader is connected to as well as the number of the reader if the device has more than one reader.
- 3) By pressing the  button in the Main Key Code field read the code of the key.

Each key from the key list at Keys tab is assigned to a number of attributes (see Figure 16) which can be specified or revised:

Key Name (the textual field above the key toolbar)

Type the textual name (or comment) which will be shown in the key list identifying the key.

Key Type

Specify the Key Type. Select *User* value if the key is intended to arm/disarm alarm loops of the device, or *Master* value if the key is intended for programming new User keys by hardware (see *Electronic Keys* section of this Manual).

Key Is Disabled

This switch provides easy key locking/unlocking. When the flag is set the key is disabled. It can be necessary, for example, if the key is stolen or lost, or should be temporary disused for any reason.

Arm/ Disarm

Define or change the status of the key.


In the Arm string tick the boxes below those loops of the Signal-10 which the key is permitted to arm. Similarly, and in the Disarm string tick the boxes below those loops of the Signal-10 which the key is permitted to disarm.

For Master keys the programmed statuses will be inherited by all the User keys which then will be programmed by hardware using this Master key.

Delete Key

The term 'delete' can have two meanings for keys in the UProg Configuration Tools. A key can be physically deleted from the device memory, or can be marked as 'deleted' when the key descriptor is excluded from the list of keys but is stored in the device memory and can be easily restored.

To delete *all keys physically from the device memory*, select the  button from the toolbar at the Keys tab. The deleted key cannot be restored.

In order to delete any key descriptor from the list of keys (to mark the key as 'deleted') select this key in the list and click on the  button. If the Show Deleted Keys switch is set on (the  button is sunken) then the descriptors of 'deleted' keys are shown with grey text; otherwise the 'deleted' keys are hidden.

In order to restore a 'deleted' key select it in the list of keys (the Show Deleted Keys switch must be set on) and click on the  button.

Operations with the List of Keys

UProg Configuration Tool offers some additional utilities to operate keys.

The list of keys can be exported to a textual file or MS Word file by means of the  button. If keys are written to an MS Word file, the keys are written along with all programmed attributes, while if keys are written to a text file, only key codes, names and order number in the list are recorded.

The UProg is supplied with two find commands, namely – the Find Key Duplicates  (to find all the keys which have the same code but different descriptors) and Find Key  (to find key descriptors by the given code).

Besides, UProg is supplied with the Defragment Key Memory tool (the  button) intended for reordering the list of keys and the defragmenting the device key memory. Use this command to facilitate key handling and to clear the device memory from the keys which are marked as deleted if the list of keys are full (the last key in the list has the number 85). The algorithm of defragmentation works by the principle of replacing the first found 'deleted' key by an active key. Thus, the numbers of the keys in the list after defragmentation will differ.

Save Results

When key handling is completed, the amended key list **MUST BE WRITTEN** to the Signal-10 memory by means of Write Keys to Memory tool (pressing the  button).

NOTES: After activation the described command all previously written keys at the device memory are cleared

The key memory area is isolated from other memory areas and is handled separately. To save keys, use only the toolbar Write Keys to Memory tool rather than other UProg save commands.

The keys with their attributes can also be written to a special file with the extension of **.ki** which then can be loaded to an UProg at this/another PC, for example, to facilitate setting of other Signal-10 devices. The Save Keys to File command (the  toolbar button) is to be used for this purpose.

Programming of Keys by Hardware

For hardware programming of User keys (which are intended for arming/disarming alarm loops of this device), the device should be switched to the User Key Programming mode by presenting a Master key to the device reader (see Section *Electronic Keys*).

Also one Master key can be programmed by hardware.

Programming of a Master Key by Hardware

As opposed to Master key programming by means of UProg Configuration Tool (see above) only one Master key can be programmed by hardware.

WARNING: Each hardware programming of a new Master key causes all keys stored in the device memory to *be deleted*.

In order to switch the device to the Master Key Programming Mode, press the device tamper by a specific way: long pressing – short pressing – long pressing. If you successfully pressed the tamper switch as mentioned above, the device plays the first part of the Programming melody while READY LED and the reader LED start flashing.

Then, within 10 seconds touch the device reader with an electronic key. If the device successfully reads the code of the presented key, it deletes all memorized keys and writes the new key code to its memory with the Master attribute and the status enabling the key to arm/disarm all the 10 alarm loops of the device. After that the device exits from Master Key Programming Mode.

If the device fails to read a code of the electronic key within 10 seconds, it automatically exits from the Master Key Programming mode. When exiting the Master Key Programming Mode, the device plays the final part of the Programming melody.

The Master Key can be used to switch the Signal-10 device to the User Key Programming Mode to program User keys with the status similar by default to the status of this Master Key (arming/disarming all the 10 alarm loops of the device is enabled).

Programming of User Keys by Hardware

In order to switch the device to the User Key Programming mode, touch the reader with a Master key. If the Master key is successfully read and perceived, the device activates the programming mode and plays a melody while READY LED and the reader LED start blinking.

The following functions are available in this mode:

- Registering of new User keys
- Changing privileges of already existing User keys

The Signal-10 device exits from the User Key Programming mode:

- When the Master Key is presented to the device reader once again
- After 30 seconds time out since the last key programming or status changing
- After 10 seconds time out since entered the User Key Programming mode if neither key is presented to the reader nor key status is changed

When the device exits from the User Key Programming mode, a melody sounds.

Each User key can be configured to arm/disarm an arbitrary group of device alarm loops. The following rights to control each alarm loop of this group can be assigned to the User key:

- arm/disarm
- arm only
- disarm only

If the User key has no control rights assigned to a specific alarm loop, this loop is not included to the selected group.

A combination of access rights assigned to the key for all the alarm loops within the selected group is called *Key Status*. When the device switches to the User Key Programming mode, a current status of a User key inherits from the status of the presented Master Key (by default). In the User Key Programming mode the current status of the presented User key is displayed by the device LEDs 1 – 10 (see Table 12).

Table 12. How the 1-10 Signal-10 LEDs Display a Key Status

Key Rights to Arm/Disarm a Loop	Behavior of the Related LED
Arm/Disarm	Flashes red and green alternately
Arm Only	Flashes red
Disarm Only	Flashes green
Neither Arm Nor Disarm	Flashes yellow or is off

If needed, you can change the status of a User key inherited from the Master key initiated the key hardware programming by long pressing on the device tamper switch. After doing so the device starts the procedure of assigning key rights.

After tamper switch having been released the LED#1 starts blinking 2X faster, thus indicating that now you can modify control rights of the current key for the alarm loop #1. Select appropriate rights for this alarm loop by gradual short pressing on the tamper switch. During this process LED#1 changes its indication in accordance with the current right settings as shown in Table 12. When a LED starts flashing with yellow, this means that the related alarm loop is removed from the group of the alarm loops that can be controlled with the configured key.

After selecting control rights for the current alarm loop, make long pressing on the tamper switch to select control rights for the next alarm loop. After that the LED of the corresponding alarm loop starts blinking 2X faster, while the LED of the previous alarm loop retains blinking (or switches OFF if no control rights were assigned to the key for this alarm loop). Alarm loops are searched sequentially and in closed loop manner: after programming control rights of the key for the alarm loop #10, next long pressing the tamper switch will lead to setting control rights of the key for the alarm loop #1.

Once the status of the current key is configured, present the key to a reader in order to write the code of the key and its modified control rights to the device non-volatile memory.

MAINTENANCE



To make sure your Signal-10 device keeps proper operability it must be inspected by a competent specialist at least on receipt and annually. The inspection algorithm shall include:

- Visual checking Signal-10 for contaminations and mechanical damage
- Verifying Signal-10 for secure mounting and wire connection conditions
- Inspection of Signal-10 operability in accordance with the techniques shown below

The Signal-10 must be tested under the following ambient conditions:

- Temperature $25^{\circ} \pm 10^{\circ}\text{C}$
- Relative humidity $45 \div 80 \%$
- Atmospheric pressure $630 \div 800 \text{ mm Hg}$

Figure 17 shows the scheme of wiring the Signal-10 in order to inspect its operability. The operability inspection lasts no more than 10 minutes.



NOTE:

Power off the device before connecting and disconnecting wires

SIGNAL-10 OPERABILITY INSPECTION

Inspect the device operability by doing the following:

- a) Power-up the device. The device built-in sounder should play the Starting signal.
- b) Ensure the S2000/S2000M console or another network controller being in use displays the events of founding the device with the address of the Signal-10 and the device reset.
- c) Measure the device consumed current and ensure its value doesn't exceed the declared value (see the Specifications section of this Manual).

TESTING THE SIGNAL-10 IN SELF-DIAGNOSTIC MODE



WARNING:

Before testing the Signal-10 in Self-Diagnostic mode detach its outputs from the executive circuits if activation of executive devices is inadmissible during inspection

To switch the device to the Self-Diagnostic mode make short-short-short-long pressing on the device tamper switch.

The device must behave as follows:

- a) The device sounder plays a melody
- b) READY LED flashes red twice per second
- c) 1 – 10 LEDs is lit with red within 3 seconds
- d) 1 – 10 LEDs sequentially flashes red and green alternately for 1s each. Simultaneously the device outputs sequentially switches on with time interval of 2s

The last device output (the LAM) switching off, the Signal-10 automatically exits Self-Diagnostic mode and returns in Operation mode.

ALARM LOOP INSPECTION

Inspect operability of each the Signal-10 alarm loop by doing the following:

1. Remove any load from the alarm input (LP) and measure the voltage across the alarm input contact. The voltage value must range from 26.5 V to 27.5 V.
2. Connect the 4.7 k Ω resistor to the alarm input (LP) and read the loop ADC value by means of the S2000/S2000M console by doing the following:

ENTER CODE: _

Enter your PIN-code by means of S2000M

◆ 5 REQUEST INFO

Select REQUEST INFO command by  or  console button and press **ENTER**, or use the **5** console button as the hot key

◆ 52 ZONE ADC

Select ZONE ADC command by  or  console button and press **ENTER**, or use the **2** console button as the hot key

ADDRESS: _

Enter the current Signal-10 network address or select the valid value by the  or  console buttons and press **ENTER**

ENTER LOOP#: _

Tape the valid loop number or select it by means of the  and  buttons and press **ENTER**

The values which will be output by the console must range from 46 to 50.

To measure ADC values you can also use software tools such as the UProg (see Figure 10, стр. 67), SHLEIFES and others.




Figure 17. Wiring the Signal-10 for Operability Inspection

PA1: a milliammeter
HL1...HL4: single LEDs
R1...R4: resistors 1/4W – 2kΩ
VD1, VD2: 1N4007 diodes

ANNEX. CURRENT CONSUMPTION ESTIMATION

Table 13 shows the standard values of current consumed by the Signal-10 in main operation modes in case of standard operating.

Table 13. Standard Current Consumption Values

Device Conditions	Mode	Power Voltage	
		12 V	24 V
All alarm loops of the Signal-10 are armed and there are no detectors powered via alarm loops	Operation	220 mA	110 mA
	Alarm	230 mA	115 mA
All alarm loops of the Signal-10 are armed, all detectors are powered via alarm loops, and total current consumption in each alarm loop is 3 mA (totally, I = 30 mA)	Operation	310 mA	150 mA
	Fire Alarm (two detector has actuated)	410 mA	200 mA

If alarm loops of the device are loaded partially (that is, some detectors are powered via the loop but its totally consumed current doesn't exceed the maximum value) then the current consumed by the Signal-10 can be considered to increase in direct proportion to the current consumed by the detectors.

In such a way, if all termination resistors are installed, the current consumed by the Signal-10 can be calculated by formulas:

In case of device being powered from a **12 V** power supply:

$$I = 2.75 \times i + 220 \text{ [mA]}$$

In case of device being powered from a **24 V** power supply:

$$I = 1.23 \times i + 110 \text{ [mA]}$$

Where: **I** is the total device consumed current (without regard to external annunciators) [mA],

i is the current consumed by active detectors from alarm loops [mA].

The total time of battery-backed device operation, taking into account the margin 25%, is calculated by formula:

$$T = 750 \times W / I \text{ [ч]}$$

Where: **W** is the capacity of a backup battery [Ah],

I is the current consumed by the device [mA].

BOLID ONE YEAR LIMITED WARRANTY

Bolid Company and its divisions and subsidiaries («Seller»), 4 Pionerskaya Str., Korolev 141070, Moscow Region, Russia warrants its security equipment (the «product») to be free from defects in materials and workmanship for one year from date of original purchase, under normal use and service. Seller's obligation is limited to repairing or replacing, at its option, free of charge for parts or labor, any product proven to be defective in materials or workmanship under normal use and service. Seller is not responsible for results where the product is used improperly, where it is used for any application it is not intended for, used under unacceptable environmental conditions and mishandled or stored under improperly. Seller shall have no obligation under this warranty or otherwise if the product is altered or improperly repaired or serviced by anyone other than the Seller. In case of defect, contact the security professional who installed and maintains your security equipment or the Seller for product repair.

This one year Limited Warranty is in lieu of all other express warranties, obligations or liabilities. THERE ARE NO EXPRESS WARRANTIES, WHICH EXTEND BEYOND THE FACE HEREOF. ANY IMPLIED WARRANTIES, OBLIGATIONS OR LIABILITIES MADE BY SELLER IN CONNECTION WITH THIS PRODUCT, INCLUDING ANY IMPLIED WARRANTY OF MERCHANTABILITY, OR FITNESS FOR A PARTICULAR PURPOSE OR OTHERWISE, ARE LIMITED IN DURATION TO A PERIOD OF ONE YEAR FROM THE DATE OF ORIGINAL PURCHASE. ANY ACTION FOR BREACH OF ANY WARRANTY, INCLUDING BUT NOT LIMITED TO ANY IMPLIED WARRANTY OF MERCHANTABILITY, MUST BE BROUGHT WITHIN 12 MONTHS FROM DATE OF ORIGINAL PURCHASE. IN NO CASE SHALL SELLER BE LIABLE TO ANYONE FOR ANY CONSEQUENTIAL OR INCIDENTAL DAMAGES FOR BREACH OF THIS OR ANY OTHER WARRANTY, EXPRESS OR IMPLIED, OR UPON ANY OTHER BASIS OF LIABILITY WHATSOEVER, EVEN IF THE LOSS OR DAMAGE IS CAUSED BY THE SELLER'S OWN NEGLIGENCE OR FAULT. Some countries do not allow limitation on how long an implied warranty lasts or the exclusion or limitation of incidental or consequential damages, so the above limitation or exclusion may not apply to you.

Seller does not represent that the product may not be compromised or circumvented; that the product will prevent any personal injury or property loss by burglary, robbery, fire or otherwise; or that the product will in all cases provide adequate warning or protection. Buyer understands that a properly installed and maintained alarm may only reduce the risk of a burglary, robbery, fire or other events occurring without providing an alarm, but it is not insurance or guarantee that such will not occur or that there will be no personal injury or property loss as a result. CONSEQUENTLY, SELLER SHALL HAVE NO LIABILITY FOR ANY PERSONAL INJURY, PROPERTY DAMAGE OR OTHER LOSS BASED ON A CLAIM THE PRODUCT FAILED TO GIVE WARNING. HOWEVER, IF SELLER IS HELD LIABLE, WHETHER DIRECTLY OR INDIRECTLY, FOR ANY LOSS OR DAMAGE ARISING UNDER THIS LIMITED WARRANTY OR OTHERWISE, REGARDLESS OF CAUSE OR ORIGIN, SELLER'S MAXIMUM LIABILITY SHALL NOT IN ANY CASE EXCEED THE PURCHASE PRICE OF THE PRODUCT, WHICH SHALL BE THE COMPLETE AND EXCLUSIVE REMEDY AGAINST SELLER. This warranty gives you specific legal rights, and you may also have other rights which vary from country to country. No increase or alteration, written or verbal, to this warranty is authorized.

**4 Pionerskaya Str., Korolev 141070,
Moscow Region, Russia
Phone/fax: +7 495 775-71-55
Email: info@bolid.ru**

www.bolid.com
